

## **ANALYTICAL REPORT**

Job Number: 420-193340-1

SDG Number: Temple Hill

Job Description: Orange-Ulster BOCES


For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



---

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

04/12/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [Envirotestlabs/terms.com](http://Envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

**Envirotest Laboratories**

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 [www.envirotestlaboratories.com](http://www.envirotestlaboratories.com)

## METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

**METHOD / ANALYST SUMMARY**

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193340-1	Women's O/S Loading Dock BS	Drinking Water	03/16/2021 0335	03/18/2021 1055
420-193340-2	Men O/S Loading Dock BS	Drinking Water	03/16/2021 0336	03/18/2021 1055
420-193340-3	O/S Loading Dock BF	Drinking Water	03/16/2021 0337	03/18/2021 1055
420-193340-4	Boys Locker Room Coaches BS	Drinking Water	03/16/2021 0338	03/18/2021 1055
420-193340-5	Boys Locker Room BF	Drinking Water	03/16/2021 0339	03/18/2021 1055
420-193340-6	Boys Locker Room BS #1	Drinking Water	03/16/2021 0340	03/18/2021 1055
420-193340-7	Boys Locker Room #2	Drinking Water	03/16/2021 0340	03/18/2021 1055
420-193340-8	Girls Locker Room Coaches BS	Drinking Water	03/16/2021 0342	03/18/2021 1055
420-193340-9	Girls Locker Room BF	Drinking Water	03/16/2021 0343	03/18/2021 1055
420-193340-10	Girls Locker Room BS #1	Drinking Water	03/16/2021 0344	03/18/2021 1055
420-193340-11	Girls Locker Room BS #2	Drinking Water	03/16/2021 0344	03/18/2021 1055
420-193340-12	Girls Locker Room BS #3	Drinking Water	03/16/2021 0345	03/18/2021 1055
420-193340-13	Kitchen BS	Drinking Water	03/16/2021 0347	03/18/2021 1055
420-193340-14	KS #1	Drinking Water	03/16/2021 0349	03/18/2021 1055
420-193340-15	KS #2	Drinking Water	03/16/2021 0349	03/18/2021 1055
420-193340-16	KS #3	Drinking Water	03/16/2021 0349	03/18/2021 1055
420-193340-17	Dish Washer HS	Drinking Water	03/16/2021 0351	03/18/2021 1055
420-193340-18	Kitchen KF	Drinking Water	03/16/2021 0352	03/18/2021 1055
420-193340-19	Kitchen Island KS	Drinking Water	03/16/2021 0352	03/18/2021 1055
420-193340-20	KS #3	Drinking Water	03/16/2021 0353	03/18/2021 1055
420-193340-21	Health CS #1	Drinking Water	03/16/2021 0355	03/18/2021 1055
420-193340-22	Health BS #2	Drinking Water	03/16/2021 0356	03/18/2021 1055
420-193340-23	Health BS #3	Drinking Water	03/16/2021 0356	03/18/2021 1055
420-193340-24	Health Exam BS #4	Drinking Water	03/16/2021 0358	03/18/2021 1055
420-193340-25	RM 1 CS	Drinking Water	03/16/2021 0359	03/18/2021 1055
420-193340-26	RM 1BS	Drinking Water	03/16/2021 0359	03/18/2021 1055
420-193340-27	RM 7 CS	Drinking Water	03/16/2021 0400	03/18/2021 1055
420-193340-28	RM 7 BS	Drinking Water	03/16/2021 0401	03/18/2021 1055
420-193340-29	RM 2 CS	Drinking Water	03/16/2021 0402	03/18/2021 1055
420-193340-30	RM 2 BS	Drinking Water	03/16/2021 0402	03/18/2021 1055
420-193340-31	RM 3 CS	Drinking Water	03/16/2021 0403	03/18/2021 1055
420-193340-32	RM 3 BS	Drinking Water	03/16/2021 0404	03/18/2021 1055
420-193340-33	RM 4A SS	Drinking Water	03/16/2021 0404	03/18/2021 1055
420-193340-34	RM 4 CS	Drinking Water	03/16/2021 0405	03/18/2021 1055
420-193340-35	RM 4 BS	Drinking Water	03/16/2021 0405	03/18/2021 1055
420-193340-36	RM 4B KS	Drinking Water	03/16/2021 0406	03/18/2021 1055
420-193340-37	RM 5 CS	Drinking Water	03/16/2021 0407	03/18/2021 1055
420-193340-38	RM 5 BS	Drinking Water	03/16/2021 0408	03/18/2021 1055
420-193340-39	RM 6 CS	Drinking Water	03/16/2021 0409	03/18/2021 1055
420-193340-40	RM 6 BS	Drinking Water	03/16/2021 0409	03/18/2021 1055
420-193340-41	RM 8 CS	Drinking Water	03/16/2021 0410	03/18/2021 1055
420-193340-42	Main Office KS	Drinking Water	03/16/2021 0412	03/18/2021 1055
420-193340-43	Main Office Men BS	Drinking Water	03/16/2021 0412	03/18/2021 1055
420-193340-44	Main Office Women BS	Drinking Water	03/16/2021 0413	03/18/2021 1055

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193340-45	Girls O/S Main Office BS #1	Drinking Water	03/16/2021 0415	03/18/2021 1055
420-193340-46	Girls O/S Main Office BS #2	Drinking Water	03/16/2021 0415	03/18/2021 1055
420-193340-47	Boys O/S Main Office BS #1	Drinking Water	03/16/2021 0416	03/18/2021 1055
420-193340-48	Boys O/S Main Office BS #2	Drinking Water	03/16/2021 0416	03/18/2021 1055
420-193340-49	Boys O/S Main Office BS #3	Drinking Water	03/16/2021 0417	03/18/2021 1055
420-193340-50	O/S RM 15 BF	Drinking Water	03/16/2021 0418	03/18/2021 1055
420-193340-51	RM 15 CS	Drinking Water	03/16/2021 0418	03/18/2021 1055
420-193340-52	RM 15 BS	Drinking Water	03/16/2021 0419	03/18/2021 1055
420-193340-53	O/S RM 17 Women BS	Drinking Water	03/16/2021 0419	03/18/2021 1055
420-193340-54	O/S RM 17 Men BS	Drinking Water	03/16/2021 0420	03/18/2021 1055
420-193340-55	RM 14 CS	Drinking Water	03/16/2021 0421	03/18/2021 1055
420-193340-56	RM 13 CS	Drinking Water	03/16/2021 0422	03/18/2021 1055
420-193340-57	RM 12 CS	Drinking Water	03/16/2021 0422	03/18/2021 1055
420-193340-58	Library K-Wing CS	Drinking Water	03/16/2021 0423	03/18/2021 1055
420-193340-59	RM 11 CS	Drinking Water	03/16/2021 0424	03/18/2021 1055
420-193340-60	RM 12 CS	Drinking Water	03/16/2021 0425	03/18/2021 1055
420-193340-61	O/S Primary Playroom BS #1	Drinking Water	03/16/2021 0427	03/18/2021 1055
420-193340-62	O/S Primary Playroom BS #2	Drinking Water	03/16/2021 0427	03/18/2021 1055
420-193340-63	Men O/S Primary Playroom BS #1	Drinking Water	03/16/2021 0428	03/18/2021 1055
420-193340-64	Men O/S Primary Playroom BS #2	Drinking Water	03/16/2021 0428	03/18/2021 1055
420-193340-65	Men O/S Primary Playroom BS #3	Drinking Water	03/16/2021 0429	03/18/2021 1055
420-193340-66	Women O/S Primary Playroom BS #1	Drinking Water	03/16/2021 0430	03/18/2021 1055
420-193340-67	Women O/S Primary Playroom BS #2	Drinking Water	03/16/2021 0430	03/18/2021 1055
420-193340-68	Women O/S Primary Playroom BS #3	Drinking Water	03/16/2021 0431	03/18/2021 1055
420-193340-69	Cafe BF #1	Drinking Water	03/16/2021 0432	03/18/2021 1055
420-193340-70	Cafe BF #2	Drinking Water	03/16/2021 0433	03/18/2021 1055
420-193340-71	Faculty Lounge KS #1	Drinking Water	03/16/2021 0433	03/18/2021 1055
420-193340-72	Faculty Lounge KS #2	Drinking Water	03/16/2021 0433	03/18/2021 1055
420-193340-73	RM 42 CS	Drinking Water	03/16/2021 0435	03/18/2021 1055
420-193340-74	Security Office KS	Drinking Water	03/16/2021 0435	03/18/2021 1055
420-193340-75	O/S 225 BF	Drinking Water	03/16/2021 0437	03/18/2021 1055
420-193340-76	Mens O/S RM 223 BS	Drinking Water	03/16/2021 0438	03/18/2021 1055
420-193340-77	Women O/S 225 BS	Drinking Water	03/16/2021 0438	03/18/2021 1055
420-193340-78	RM 218 KS	Drinking Water	03/16/2021 0439	03/18/2021 1055
420-193340-79	O/S 224A BF #1	Drinking Water	03/16/2021 0441	03/18/2021 1055
420-193340-80	O/S 224A BF #2	Drinking Water	03/16/2021 0441	03/18/2021 1055
420-193340-81	2nd Floor Girls BS #1	Drinking Water	03/16/2021 0443	03/18/2021 1055

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193340-82	2nd Floor Girls BS #2	Drinking Water	03/16/2021 0443	03/18/2021 1055
420-193340-83	2nd Floor Girls BS #3	Drinking Water	03/16/2021 0444	03/18/2021 1055
420-193340-84	2nd Floor Girls BS #4	Drinking Water	03/16/2021 0444	03/18/2021 1055
420-193340-85	2nd Floor Girls BS #5	Drinking Water	03/16/2021 0445	03/18/2021 1055
420-193340-86	2nd Floor Girls BS #6	Drinking Water	03/16/2021 0445	03/18/2021 1055
420-193340-87	2nd Floor Boys BS #1	Drinking Water	03/16/2021 0446	03/18/2021 1055
420-193340-88	2nd Floor Boys BS #2	Drinking Water	03/16/2021 0446	03/18/2021 1055
420-193340-89	2nd Floor Boys BS #3	Drinking Water	03/16/2021 0447	03/18/2021 1055
420-193340-90	2nd Floor Boys BS #4	Drinking Water	03/16/2021 0448	03/18/2021 1055
420-193340-91	2nd Floor Boys BS #5	Drinking Water	03/16/2021 0448	03/18/2021 1055
420-193340-92	2nd Floor Boys BS #6	Drinking Water	03/16/2021 0449	03/18/2021 1055
420-193340-93	RM 224A KS	Drinking Water	03/16/2021 0450	03/18/2021 1055
420-193340-94	237 CS #1	Drinking Water	03/16/2021 0452	03/18/2021 1055
420-193340-95	237 CS #2	Drinking Water	03/16/2021 0452	03/18/2021 1055
420-193340-96	237 CS #3	Drinking Water	03/16/2021 0455	03/18/2021 1055
420-193340-97	237 CS #4	Drinking Water	03/16/2021 0455	03/18/2021 1055
420-193340-98	237 CS #5	Drinking Water	03/16/2021 0456	03/18/2021 1055
420-193340-99	RM 226 CS	Drinking Water	03/16/2021 0457	03/18/2021 1055
420-193340-100	RM 228 CS	Drinking Water	03/16/2021 0458	03/18/2021 1055
420-193340-101	239 CS	Drinking Water	03/16/2021 0458	03/18/2021 1055
420-193340-102	RM 141 CS	Drinking Water	03/16/2021 0500	03/18/2021 1055
420-193340-103	RM 126B CS	Drinking Water	03/16/2021 0501	03/18/2021 1055
420-193340-104	RM 139 CS	Drinking Water	03/16/2021 0501	03/18/2021 1055
420-193340-105	RM 126A CS	Drinking Water	03/16/2021 0502	03/18/2021 1055
420-193340-106	RM 137 CS	Drinking Water	03/16/2021 0503	03/18/2021 1055
420-193340-107	RM 124 CS	Drinking Water	03/16/2021 0503	03/18/2021 1055
420-193340-108	1st Floor Women BS #1	Drinking Water	03/16/2021 0504	03/18/2021 1055
420-193340-109	1st Floor Women BS #2	Drinking Water	03/16/2021 0505	03/18/2021 1055
420-193340-110	1st Floor Men BS #1	Drinking Water	03/16/2021 0506	03/18/2021 1055
420-193340-111	1st Floor Men BS #2	Drinking Water	03/16/2021 0506	03/18/2021 1055
420-193340-112	O/S 129 BF #1	Drinking Water	03/16/2021 0509	03/18/2021 1055
420-193340-113	O/S 129 BF #2	Drinking Water	03/16/2021 0508	03/18/2021 1055
420-193340-114	1st Floor Boys BS #1	Drinking Water	03/16/2021 0509	03/18/2021 1055
420-193340-115	1st Floor Boys BS #2	Drinking Water	03/16/2021 0509	03/18/2021 1055
420-193340-116	1st Floor Boys BS #3	Drinking Water	03/16/2021 0510	03/18/2021 1055
420-193340-117	1st Floor Boys BS #4	Drinking Water	03/16/2021 0510	03/18/2021 1055
420-193340-118	1st Floor Boys #5	Drinking Water	03/16/2021 0510	03/18/2021 1055
420-193340-119	1st Floor Girls BS #1	Drinking Water	03/16/2021 0511	03/18/2021 1055
420-193340-120	1st Floor Girls BS #2	Drinking Water	03/16/2021 0511	03/18/2021 1055
420-193340-121	1st Floor Girls BS #3	Drinking Water	03/16/2021 0512	03/18/2021 1055
420-193340-122	1st Floor Girls BS #4	Drinking Water	03/16/2021 0512	03/18/2021 1055
420-193340-123	1st Floor Girls BS #5	Drinking Water	03/16/2021 0513	03/18/2021 1055
420-193340-124	1st Floor Girls BS #6	Drinking Water	03/16/2021 0513	03/18/2021 1055
420-193340-125	Music Left M1 BF	Drinking Water	03/16/2021 0516	03/18/2021 1055
420-193340-126	Music Left M1 SS	Drinking Water	03/16/2021 0517	03/18/2021 1055
420-193340-127	Music Right SS	Drinking Water	03/16/2021 0518	03/18/2021 1055

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Client Matrix</b>	<b>Date/Time Sampled</b>	<b>Date/Time Received</b>
420-193340-128	Math Lab RM 258 CS	Drinking Water	03/16/2021 0519	03/18/2021 1055

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Women's O/S Loading Dock BS  
**Lab Sample ID:** 420-193340-1

Date Sampled: 03/16/2021 0335  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1522	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.30	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Men O/S Loading Dock BS  
**Lab Sample ID:** 420-193340-2

Date Sampled: 03/16/2021 0336  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1531	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.80	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S Loading Dock BF  
**Lab Sample ID:** 420-193340-3

Date Sampled: 03/16/2021 0337  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1533	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys Locker Room Coaches BS  
**Lab Sample ID:** 420-193340-4

Date Sampled: 03/16/2021 0338  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1535		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	17.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys Locker Room BF  
**Lab Sample ID:** 420-193340-5

Date Sampled: 03/16/2021 0339  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1537	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys Locker Room BS #1  
**Lab Sample ID:** 420-193340-6

Date Sampled: 03/16/2021 0340  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1540	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys Locker Room #2  
**Lab Sample ID:** 420-193340-7

Date Sampled: 03/16/2021 0340  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1546	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.09	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls Locker Room Coaches BS  
**Lab Sample ID:** 420-193340-8

Date Sampled: 03/16/2021 0342  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1548	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.99	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls Locker Room BF  
**Lab Sample ID:** 420-193340-9

Date Sampled: 03/16/2021 0343  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1550	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls Locker Room BS #1  
**Lab Sample ID:** 420-193340-10

Date Sampled: 03/16/2021 0344  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1553	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.55	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls Locker Room BS #2  
**Lab Sample ID:** 420-193340-11

Date Sampled: 03/16/2021 0344  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1555	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	27.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls Locker Room BS #3  
**Lab Sample ID:** 420-193340-12

Date Sampled: 03/16/2021 0345  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1559	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	22.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Kitchen BS  
**Lab Sample ID:** 420-193340-13

Date Sampled: 03/16/2021 0347  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1601	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	14.2	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** KS #1  
**Lab Sample ID:** 420-193340-14

Date Sampled: 03/16/2021 0349  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1604	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.32	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** KS #2  
**Lab Sample ID:** 420-193340-15

Date Sampled: 03/16/2021 0349  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1606	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	6.25	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** KS #3  
**Lab Sample ID:** 420-193340-16

Date Sampled: 03/16/2021 0349  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1612	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	1.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Dish Washer HS  
**Lab Sample ID:** 420-193340-17

Date Sampled: 03/16/2021 0351  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1615	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	14.7	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Kitchen KF  
**Lab Sample ID:** 420-193340-18

Date Sampled: 03/16/2021 0352  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1617	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.75	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Kitchen Island KS  
**Lab Sample ID:** 420-193340-19

Date Sampled: 03/16/2021 0352  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1619	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.02	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** KS #3  
**Lab Sample ID:** 420-193340-20

Date Sampled: 03/16/2021 0353  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1621	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.32	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Health CS #1  
**Lab Sample ID:** 420-193340-21

Date Sampled: 03/16/2021 0355  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1623	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Health BS #2  
**Lab Sample ID:** 420-193340-22

Date Sampled: 03/16/2021 0356  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1632	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.32	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Health BS #3  
**Lab Sample ID:** 420-193340-23

Date Sampled: 03/16/2021 0356  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1639	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.51	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Health Exam BS #4  
**Lab Sample ID:** 420-193340-24

Date Sampled: 03/16/2021 0358  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1641	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.76	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 1 CS  
**Lab Sample ID:** 420-193340-25

Date Sampled: 03/16/2021 0359  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1643	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.63	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 1BS  
**Lab Sample ID:** 420-193340-26

Date Sampled: 03/16/2021 0359  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1645	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	6.17	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 7 CS  
**Lab Sample ID:** 420-193340-27

Date Sampled: 03/16/2021 0400  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1647	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	5.07	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 7 BS  
**Lab Sample ID:** 420-193340-28

Date Sampled: 03/16/2021 0401  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1650	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 2 CS  
**Lab Sample ID:** 420-193340-29

Date Sampled: 03/16/2021 0402  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1652	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.32	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 2 BS  
**Lab Sample ID:** 420-193340-30

Date Sampled: 03/16/2021 0402  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1654	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.36	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 3 CS  
**Lab Sample ID:** 420-193340-31

Date Sampled: 03/16/2021 0403  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1656	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.67	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 3 BS  
**Lab Sample ID:** 420-193340-32

Date Sampled: 03/16/2021 0404  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1705	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.16	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 4A SS  
**Lab Sample ID:** 420-193340-33

Date Sampled: 03/16/2021 0404  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1707	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	26.2 g	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 4 CS  
**Lab Sample ID:** 420-193340-34

Date Sampled: 03/16/2021 0405  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1709		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 4 BS  
**Lab Sample ID:** 420-193340-35

Date Sampled: 03/16/2021 0405  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1711	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	5.42	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 4B KS  
**Lab Sample ID:** 420-193340-36

Date Sampled: 03/16/2021 0406  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1714	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	57.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 5 CS  
**Lab Sample ID:** 420-193340-37

Date Sampled: 03/16/2021 0407  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1716	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.31	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 5 BS  
**Lab Sample ID:** 420-193340-38

Date Sampled: 03/16/2021 0408  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1718	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	7.67	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 6 CS  
**Lab Sample ID:** 420-193340-39

Date Sampled: 03/16/2021 0409  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1720		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000		
Pb	33.0	g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 6 BS  
**Lab Sample ID:** 420-193340-40

Date Sampled: 03/16/2021 0409  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1722	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.19	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 8 CS  
**Lab Sample ID:** 420-193340-41

Date Sampled: 03/16/2021 0410  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1725	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	2.22	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Main Office KS  
**Lab Sample ID:** 420-193340-42

Date Sampled: 03/16/2021 0412  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1738	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	4.28	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Main Office Men BS  
**Lab Sample ID:** 420-193340-43

Date Sampled: 03/16/2021 0412  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1740	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	6.41	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID: Main Office Women BS**  
**Lab Sample ID: 420-193340-44**

Date Sampled: 03/16/2021 0413  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1742	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	5.75	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls O/S Main Office BS #1  
**Lab Sample ID:** 420-193340-45

Date Sampled: 03/16/2021 0415  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1744	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	4.55	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Girls O/S Main Office BS #2  
**Lab Sample ID:** 420-193340-46

Date Sampled: 03/16/2021 0415  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1746	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	4.68	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys O/S Main Office BS #1  
**Lab Sample ID:** 420-193340-47

Date Sampled: 03/16/2021 0416  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1749	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.96	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys O/S Main Office BS #2  
**Lab Sample ID:** 420-193340-48

Date Sampled: 03/16/2021 0416  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1751	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.41	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Boys O/S Main Office BS #3  
**Lab Sample ID:** 420-193340-49

Date Sampled: 03/16/2021 0417  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1757		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	9.40	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S RM 15 BF  
**Lab Sample ID:** 420-193340-50

Date Sampled: 03/16/2021 0418  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1759		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 15 CS  
**Lab Sample ID:** 420-193340-51

Date Sampled: 03/16/2021 0418  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1802	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	39.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 15 BS  
**Lab Sample ID:** 420-193340-52

Date Sampled: 03/16/2021 0419  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1806	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	20.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S RM 17 Women BS  
**Lab Sample ID:** 420-193340-53

Date Sampled: 03/16/2021 0419  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1808	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.51	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S RM 17 Men BS  
**Lab Sample ID:** 420-193340-54

Date Sampled: 03/16/2021 0420  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1810	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.19	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 14 CS  
**Lab Sample ID:** 420-193340-55

Date Sampled: 03/16/2021 0421  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1813	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 13 CS  
**Lab Sample ID:** 420-193340-56

Date Sampled: 03/16/2021 0422  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1815	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	163 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 12 CS  
**Lab Sample ID:** 420-193340-57

Date Sampled: 03/16/2021 0422  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1817	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.32	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Library K-Wing CS  
**Lab Sample ID:** 420-193340-58

Date Sampled: 03/16/2021 0423  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1823	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	103 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 11 CS  
**Lab Sample ID:** 420-193340-59

Date Sampled: 03/16/2021 0424  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1826	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.46	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 12 CS  
**Lab Sample ID:** 420-193340-60

Date Sampled: 03/16/2021 0425  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021	1911	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.03	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S Primary Playroom BS #1  
**Lab Sample ID:** 420-193340-61

Date Sampled: 03/16/2021 0427  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1830		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S Primary Playroom BS #2  
**Lab Sample ID:** 420-193340-62

Date Sampled: 03/16/2021 0427  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021 1839		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Men O/S Primary Playroom BS #1  
**Lab Sample ID:** 420-193340-63

Date Sampled: 03/16/2021 0428  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1841	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.58	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Men O/S Primary Playroom BS #2  
**Lab Sample ID:** 420-193340-64

Date Sampled: 03/16/2021 0428  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1843	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	6.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Men O/S Primary Playroom BS #3  
**Lab Sample ID:** 420-193340-65

Date Sampled: 03/16/2021 0429  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1850	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.69	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Women O/S Primary Playroom BS #1  
**Lab Sample ID:** 420-193340-66

Date Sampled: 03/16/2021 0430  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1852	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Women O/S Primary Playroom BS #2  
**Lab Sample ID:** 420-193340-67

Date Sampled: 03/16/2021 0430  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 1913	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	2.91	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Women O/S Primary Playroom BS #3  
**Lab Sample ID:** 420-193340-68

Date Sampled: 03/16/2021 0431  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 1915	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.43	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Cafe BF #1  
**Lab Sample ID:** 420-193340-69

Date Sampled: 03/16/2021 0432  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1858	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Cafe BF #2  
**Lab Sample ID:** 420-193340-70

Date Sampled: 03/16/2021 0433  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1901	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Faculty Lounge KS #1  
**Lab Sample ID:** 420-193340-71

Date Sampled: 03/16/2021 0433  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1903	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Faculty Lounge KS #2  
**Lab Sample ID:** 420-193340-72

Date Sampled: 03/16/2021 0433  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1907	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.13	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 42 CS  
**Lab Sample ID:** 420-193340-73

Date Sampled: 03/16/2021 0435  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1909	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	12.4	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Security Office KS  
**Lab Sample ID:** 420-193340-74

Date Sampled: 03/16/2021 0435  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1916	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	2.31	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S 225 BF  
**Lab Sample ID:** 420-193340-75

Date Sampled: 03/16/2021 0437  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1918	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Mens O/S RM 223 BS  
**Lab Sample ID:** 420-193340-76

Date Sampled: 03/16/2021 0438  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1920	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.42	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Women O/S 225 BS  
**Lab Sample ID:** 420-193340-77

Date Sampled: 03/16/2021 0438  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1922	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	4.08	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 218 KS  
**Lab Sample ID:** 420-193340-78

Date Sampled: 03/16/2021 0439  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1925	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	45.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S 224A BF #1  
**Lab Sample ID:** 420-193340-79

Date Sampled: 03/16/2021 0441  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1927	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S 224A BF #2  
**Lab Sample ID:** 420-193340-80

Date Sampled: 03/16/2021 0441  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1929	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #1  
**Lab Sample ID:** 420-193340-81

Date Sampled: 03/16/2021 0443  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1931	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	14.9	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #2  
**Lab Sample ID:** 420-193340-82

Date Sampled: 03/16/2021 0443  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1944	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	5.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #3  
**Lab Sample ID:** 420-193340-83

Date Sampled: 03/16/2021 0444  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021 1946	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	5.04	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #4  
**Lab Sample ID:** 420-193340-84

Date Sampled: 03/16/2021 0444  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1949	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.57	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #5  
**Lab Sample ID:** 420-193340-85

Date Sampled: 03/16/2021 0445  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1951	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	11.5	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Girls BS #6  
**Lab Sample ID:** 420-193340-86

Date Sampled: 03/16/2021 0445  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1953	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #1  
**Lab Sample ID:** 420-193340-87

Date Sampled: 03/16/2021 0446  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1955	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	14.5	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #2  
**Lab Sample ID:** 420-193340-88

Date Sampled: 03/16/2021 0446  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1957	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	10.7	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #3  
**Lab Sample ID:** 420-193340-89

Date Sampled: 03/16/2021 0447  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	1959	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	7.04	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #4  
**Lab Sample ID:** 420-193340-90

Date Sampled: 03/16/2021 0448  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2002	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	5.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #5  
**Lab Sample ID:** 420-193340-91

Date Sampled: 03/16/2021 0448  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2008	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	5.31	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 2nd Floor Boys BS #6  
**Lab Sample ID:** 420-193340-92

Date Sampled: 03/16/2021 0449  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2013	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	6.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 224A KS  
**Lab Sample ID:** 420-193340-93

Date Sampled: 03/16/2021 0450  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2015	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	18.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 237 CS #1  
**Lab Sample ID:** 420-193340-94

Date Sampled: 03/16/2021 0452  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021	2017
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021	1000
Pb	10.1	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 237 CS #2  
**Lab Sample ID:** 420-193340-95

Date Sampled: 03/16/2021 0452  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2019	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 237 CS #3  
**Lab Sample ID:** 420-193340-96

Date Sampled: 03/16/2021 0455  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2021	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 237 CS #4  
**Lab Sample ID:** 420-193340-97

Date Sampled: 03/16/2021 0455  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/05/2021	2023
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021	1000
Pb	1.50	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 237 CS #5  
**Lab Sample ID:** 420-193340-98

Date Sampled: 03/16/2021 0456  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2026	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	20.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 226 CS  
**Lab Sample ID:** 420-193340-99

Date Sampled: 03/16/2021 0457  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/05/2021	2028	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	6.73	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 228 CS  
**Lab Sample ID:** 420-193340-100

Date Sampled: 03/16/2021 0458  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2319	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.61	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 239 CS  
**Lab Sample ID:** 420-193340-101

Date Sampled: 03/16/2021 0458  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2322	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.86	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 141 CS  
**Lab Sample ID:** 420-193340-102

Date Sampled: 03/16/2021 0500  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2341	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	25.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 126B CS  
**Lab Sample ID:** 420-193340-103

Date Sampled: 03/16/2021 0501  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/06/2021 2344	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	35.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 139 CS  
**Lab Sample ID:** 420-193340-104

Date Sampled: 03/16/2021 0501  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2347	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	1.28	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 126A CS  
**Lab Sample ID:** 420-193340-105

Date Sampled: 03/16/2021 0502  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2350	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	2.98	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 137 CS  
**Lab Sample ID:** 420-193340-106

Date Sampled: 03/16/2021 0503  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2353	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	49.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** RM 124 CS  
**Lab Sample ID:** 420-193340-107

Date Sampled: 03/16/2021 0503  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2356	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	3.61	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Women BS #1  
**Lab Sample ID:** 420-193340-108

Date Sampled: 03/16/2021 0504  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/06/2021	2359	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	8.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Women BS #2  
**Lab Sample ID:** 420-193340-109

Date Sampled: 03/16/2021 0505  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0002	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	36.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Men BS #1  
**Lab Sample ID:** 420-193340-110

Date Sampled: 03/16/2021 0506  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021	0011	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	11.1	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Men BS #2  
**Lab Sample ID:** 420-193340-111

Date Sampled: 03/16/2021 0506  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021	0014	
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021	1000	
Pb	23.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S 129 BF #1  
**Lab Sample ID:** 420-193340-112

Date Sampled: 03/16/2021 0509  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0020		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** O/S 129 BF #2  
**Lab Sample ID:** 420-193340-113

Date Sampled: 03/16/2021 0508  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0023		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Boys BS #1  
**Lab Sample ID:** 420-193340-114

Date Sampled: 03/16/2021 0509  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0026	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	18.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Boys BS #2  
**Lab Sample ID:** 420-193340-115

Date Sampled: 03/16/2021 0509  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0029	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.61	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Boys BS #3  
**Lab Sample ID:** 420-193340-116

Date Sampled: 03/16/2021 0510  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0032		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	4.65	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Boys BS #4  
**Lab Sample ID:** 420-193340-117

Date Sampled: 03/16/2021 0510  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0035	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	5.01	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Boys #5  
**Lab Sample ID:** 420-193340-118

Date Sampled: 03/16/2021 0510  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0038		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	6.17	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #1  
**Lab Sample ID:** 420-193340-119

Date Sampled: 03/16/2021 0511  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0048		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	16.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #2  
**Lab Sample ID:** 420-193340-120

Date Sampled: 03/16/2021 0511  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0051	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	7.00	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #3  
**Lab Sample ID:** 420-193340-121

Date Sampled: 03/16/2021 0512  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0054		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	4.20	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #4  
**Lab Sample ID:** 420-193340-122

Date Sampled: 03/16/2021 0512  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0106	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	4.72	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #5  
**Lab Sample ID:** 420-193340-123

Date Sampled: 03/16/2021 0513  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0109	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	3.88	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** 1st Floor Girls BS #6  
**Lab Sample ID:** 420-193340-124

Date Sampled: 03/16/2021 0513  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0112	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	5.45	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Music Left M1 BF  
**Lab Sample ID:** 420-193340-125

Date Sampled: 03/16/2021 0516  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0115		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Music Left M1 SS  
**Lab Sample ID:** 420-193340-126

Date Sampled: 03/16/2021 0517  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0124		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	78.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Music Right SS  
**Lab Sample ID:** 420-193340-127

Date Sampled: 03/16/2021 0518  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/07/2021 0127	
Prep Method: 200.7/200.8			Date Prepared:	04/04/2021 1000	
Pb	6.45	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-193340-1  
Sdg Number: Temple Hill

**Client Sample ID:** Math Lab RM 258 CS  
**Lab Sample ID:** 420-193340-128

Date Sampled: 03/16/2021 0519  
Date Received: 03/18/2021 1055  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/07/2021 0130		
Prep Method: 200.7/200.8			Date Prepared: 04/04/2021 1000		
Pb	1.52	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:  
Sdg Number: Temple Hill

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.



## Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Temple Hill

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

## Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Temple Hill

---

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>	Sampler: J DeGraw Phone: 845-781-4887	Lab PM:  E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>193340</b> <b>1 of 9</b>
---------------------------	--	--	--	--

Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Due Date Requested: Standard Turn-Around TAT Requested (days):  PO #:  PWS #:  Project #:  Additional Contacts: Project Name: Newburgh ECSD Site: Temple Hill	<b>Analysis Requested</b>		Page: Page 1 of 1 Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA - Sodium Sulfite N - None O - MCAA P - Other (specify)
---	---	---------------------------	--	--

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/16/21	335	WOMENS O/S LOADING DOCK BS		G	DW				1	1	
3/16/21	336	MEN O/S LOADING DOCK BS		G	DW				1	1	
3/16/21	337	O/S LOADING DOCK BF		G	DW				1	1	
3/16/21	338	BOYS LOCKER ROOM COACHES BS		G	DW				1	1	
3/16/21	339	BOYS LOCKER ROOM BF		G	DW				1	1	
3/16/21	340	BOYS LOCKER ROOM BS #1		G	DW				1	1	
3/16/21	340	BOYS LOCKER ROOM #2		G	DW				1	1	
3/16/21	342	GIRLS LOCKER ROOM COACHES BS		G	DW				1	1	
3/16/21	343	GIRLS LOCKER ROOM BF		G	DW				1	1	
3/16/21	344	GIRLS LOCKER ROOM BS #1		G	DW				1	1	
3/16/21	344	GIRLS LOCKER ROOM BS #2		G	DW				1	1	
3/16/21	345	GIRLS LOCKER ROOM BS #3		G	DW				1	1	
3/16/21	347	KITCHEN BS		G	DW				1	1	
3/16/21	349	KS #1		G	DW				1	1	
3/16/21	349	KS #2		G	DW				1	1	

**420-193340-B-1**  
 Women's O/S Loading Dock BS  
 Date Sampled: 3/16/2021      420-1647601

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Preservation Added Upon Receipt:		Manufacturer/I of #:		Date:		Time:		Sample # (s):		Container Type	
Relinquished by:	<i>J DeGraw</i>	Date/Time:	3/18/21	10:05	Company:	OUBOCES	Received by:	<i>ETL</i>	Date/Time:	3/18/21	10:55	Company:	ETL
Relinquished by:		Date/Time:			Company:		Received by:		Date/Time:			Company:	
Relinquished by:		Date/Time:			Company:		Received by:		Date/Time:			Company:	

ICE Present:  Custody Seal No.: \_\_\_\_\_ Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: **10.8 °C**

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  <b>193310</b> <b>2 of 9</b>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1									
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	<table border="1"> <tr><td>Field Filtered Sample (Yes or No)</td><td></td></tr> <tr><td>Perform MS/MSD (Yes or No)</td><td></td></tr> <tr><td>Chlorine Present (Yes or No)</td><td></td></tr> <tr><td>Lead</td><td></td></tr> </table>			Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Chlorine Present (Yes or No)		Lead		<b>Preservation Codes:</b> A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
Field Filtered Sample (Yes or No)														
Perform MS/MSD (Yes or No)														
Chlorine Present (Yes or No)														
Lead														
City: Goshen		TAT Requested (days):												
State, Zip: NY, 10924		PO #:												
Phone: 845-781-4887		PWS #:												
Email: joseph.russo@ouboces.org Maureen.doherty@ouboces.org		Halina.redner@ouboces.org												
Project Name: Newburgh ECSD		Project #:												
Site: Temple Hill		Additional Contacts:												

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/16/21	349	KS #3		G	DW				1	1	
3/16/21	351	DISH WASHER HS		G	DW				1	1	
3/16/21	352	KITCHEN KF		G	DW				1	1	
3/16/21	352	KITCHEN ISLAND KS		G	DW				1	1	
3/16/21	353	KS #3		G	DW				1	1	
3/16/21	355	HEALTH CS #1		G	DW				1	1	
3/16/21	356	HEALTH BS #2		G	DW				1	1	
3/16/21	356	HEALTH BS #3		G	DW				1	1	
3/16/21	358	HEALTH EXAM BS #4		G	DW				1	1	
3/16/21	359	RM 1 CS		G	DW				1	1	
3/16/21	359	RM 1BS		G	DW				1	1	
3/16/21	400	RM 7 CS		G	DW				1	1	
3/16/21	401	RM 7 BS		G	DW				1	1	
3/16/21	402	RM 2 CS		G	DW				1	1	
3/16/21	402	RM 2 BS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P		Container Type	
Preparation Added Upon Receipt:	Manufacturer/Lot #:	Date:	Time:	Sample # (s):	
Relinquished by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/18/21 1055	Company: <i>[Signature]</i>
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
ICE Present: <input checked="" type="checkbox"/>	Custody Seal No.:	Custody Seals Intact: <input checked="" type="checkbox"/>	Cooler Temperature(s) °C/IR GUN #: 20.8 C		

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b> Client Contact: Kevin Flynn	Sampler: J DeGraw Phone: 845-781-4887	Lab PM:  E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>193340</b> <b>3 of 4</b>
---	--	--	--	--

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	<b>Analysis Requested</b>			Page: Page 1 of 1		
Address: 53 Gibson Road	TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen	PO #:						
State, Zip: NY, 10924	PWS #:						
Phone: 845-781-4887	Project #:						
Email: joseph.russo@ouboces.org Maureen.doherty@ouboces.org	Halina.redner@ouboces.org	Project #:	Additional Contacts:			Other: <b>D-Nitric Acid</b>	
Project Name: Newburgh ECSD	Site: Temple Hill	Upon Receipt Preservation verified: Y / N					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=wastefoil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/16/21	403	RM 3 CS		G	DW				1	1	
3/16/21	404	RM 3 BS		G	DW				1	1	
3/16/21	404	RM 4A SS		G	DW				1	1	
3/16/21	405	RM 4 CS		G	DW				1	1	
3/16/21	405	RM 4 BS		G	DW				1	1	
3/16/21	406	RM 4B KS		G	DW				1	1	
3/16/21	407	RM 5 CS		G	DW				1	1	
3/16/21	408	RM 5 BS		G	DW				1	1	
3/16/21	409	RM 6 CS		G	DW				1	1	
3/16/21	409	RM 6 BS		G	DW				1	1	
3/16/21	410	RM 8 CS		G	DW				1	1	
3/16/21	412	MAIN OFFICE KS		G	DW				1	1	
3/16/21	412	MAIN OFFICE MEN BS		G	DW				1	1	
3/16/21	413	MAIN OFFICE WOMEN BS		G	DW				1	1	
3/16/21	415	GIRLS O/S MAIN OFFICE BS#1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P		Container Type	
Relinquished by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: ETL
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present:  Custody Seal No.: \_\_\_\_\_ Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: 10.8

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: <b>J DeGraw</b>	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>193310</b> <b>4 of 9</b>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)  Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N		
City: Goshen		TAT Requested (days):			
State, Zip: NY, 10924		PO #:			
Phone: 845-781-4887		PWS #:			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:			
Project Name: Newburgh ECSD		Additional Contacts:			
Site: Temple Hill					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
				Preservation Code:					D		
3/16/21	415	GIRLS O/S MAIN OFFICE BS #2		G	DW				1	1	
3/16/21	416	BOYS O/S MAIN OFFICE BS #1		G	DW				1	1	
3/16/21	416	BOYS O/S MAIN OFFICE BS #2		G	DW				1	1	
3/16/21	417	BOYS O/S MAIN OFFICE BS #3		G	DW				1	1	
3/16/21	418	O/S RM 15 BF		G	DW				1	1	
3/16/21	418	RM 15 CS		G	DW				1	1	
3/16/21	419	RM 15 BS		G	DW				1	1	
3/16/21	419	O/S RM 17 WOMEN BS		G	DW				1	1	
3/16/21	420	O/S RM 17 MEN BS		G	DW				1	1	
3/16/21	421	RM 14 CS		G	DW				1	1	
3/16/21	422	RM 13 CS		G	DW				1	1	
3/16/21	422	RM 12 CS		G	DW				1	1	
3/16/21	423	LIBRARY K-WING CS		G	DW				1	1	
3/16/21	424	RM 11 CS		G	DW				1	1	
3/16/21	425	RM 12 CS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/lot #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>	3/18/21 10:55	OUBOCES	<i>[Signature]</i>	3/18/21 10:55	ETL		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
ICE Present: <input checked="" type="checkbox"/>	Custody Seal No.:	Custody Seals Intact: <input checked="" type="checkbox"/>	Cooler Temperature(s) °C/IR GUN #: <b>10.8 C</b>				

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>193340</b> <b>Sof 9</b>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES			<b>Analysis Requested</b>					Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around						Preservation Codes:  A - HCL L - EDA M B - NaOH - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate
City: Goshen		TAT Requested (days):						
State, Zip: NY , 10924		PO #:						
Phone: 845-781-4887		PWS #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:						Other: <b>D-Nitric Acid</b>
Project Name: Newburgh ECSD		Additional Contacts:						Upon Receipt Preservation verified: Y / N
Site: Temple Hill								

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/16/21	427	O/S PRIMARY PLAYROOM BF #1	G	DW				1	1	
3/16/21	427	O/S PRIMARY PLAYROOM BF #2	G	DW				1	1	
3/16/21	428	MEN O/S PRIMARY PLAYROOM BS #1	G	DW				1	1	
3/16/21	428	MEN O/S PRIMARY PLAYROOM BS #2	G	DW				1	1	
3/16/21	429	MEN O/S PRIMARY PLAYROOM BS #3	G	DW				1	1	
3/16/21	430	WOMEN O/S PRIMARY PLAYROOM BS #1	G	DW				1	1	
3/16/21	430	WOMEN O/S PRIMARY PLAYROOM BS #2	G	DW				1	1	
3/16/21	431	WOMEN O/S PRIMARY PLAYROOM BS #3	G	DW				1	1	
3/16/21	432	CAFÉ BF #1	G	DW				1	1	
3/16/21	433	CAFÉ BF #2	G	DW				1	1	
3/16/21	433	FACULTY LOUNGE KS #1	G	DW				1	1	
3/16/21	433	FACULTY LOUNGE KS #2	G	DW				1	1	
3/16/21	435	RM 42 CS	G	DW				1	1	
3/16/21	435	SECURITY OFFICE KS	G	DW				1	1	
3/16/21	437	O/S 225 BF	G	DW				1	1	

Preservation Added Upon Receipt:		Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/18/21 055	Company: ETC	
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:	
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:	

ICE Present: **NA** Custody Seal No.: Custody Seals Intact:  $\Delta$  Cooler Temperature(s) °C/IR GUN #: **10.8 °C**







**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
 Newburgh, NY 12550  
 Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  <b>193340</b> <b>8 of 9</b>
Client Contact: Kevin Flynn	Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES	<b>Analysis Requested</b>			Page: Page 1 of 1
Address: 53 Gibson Road	Due Date Requested: Standard Turn-Around	Total Number of containers Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate	L - EDA - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen	TAT Requested (days):			
State, Zip: NY, 10924	PO #:			
Phone: 845-781-4887	PWS #:			
Email: joseph.russo@ouboces.org Maureen.doherty@ouboces.org	Halina.redner@ouboces.org	Project #:	Other: <b>D-Nitric Acid</b>	
Project Name: Newburgh ECSD	Site: Temple Hill	Additional Contacts:	Upon Receipt Preservation verified: Y / N	

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, S=solid, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of containers	Special Instructions/Note:
3/16/21	503	RM 137 CS		G	DW				1	1	
3/16/21	503	RM 124 CS		G	DW				1	1	
3/16/21	504	1ST FLOOR WOMEN BS #1		G	DW				1	1	
3/16/21	505	1ST FLOOR WOMEN BS #2		G	DW				1	1	
3/16/21	506	1ST FLOOR MEN BS #1		G	DW				1	1	
3/16/21	506	1ST FLOOR MEN BS #2		G	DW				1	1	
3/16/21	509	O/S 129 BF #1		G	DW				1	1	
3/16/21	508	O/S 129 BF #2		G	DW				1	1	
3/16/21	509	1ST FLOOR BOYS BS #1		G	DW				1	1	
3/16/21	509	1ST FLOOR BOYS BS #2		G	DW				1	1	
3/16/21	510	1ST FLOOR BOYS BS #3		G	DW				1	1	
3/16/21	510	1ST FLOOR BOYS BS #4		G	DW				1	1	
3/16/21	510	1ST FLOOR BOYS #5		G	DW				1	1	
3/16/21	511	1ST FLOOR GIRLS BS #1		G	DW				1	1	
3/16/21	511	1ST FLOOR GIRLS BS #2		G	DW				1	1	

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/18/21 10:55	Company: ETC
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: *no* Custody Seal No.: Custody Seals Intact:  $\Delta$  Cooler Temperature(s) °C/IR GUN #: *10.8 C*



## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-193340-1

SDG Number: Temple Hill

**Login Number: 193340**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	10.8 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	