

## ANALYTICAL REPORT

Job Number: 420-195451-1

SDG Number: South Jr High- Newburgh ECSD

Job Description: Orange-Ulster BOCES

For:  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Attention: Jack DeGraw



---

Designee for  
Meredith W Ruthven  
Customer Service Manager  
mruthven@envirotestlaboratories.com  
06/21/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [Envirotestlabs/terms.com](http://Envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

## METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195451-1  
SDG Number: South Jr High- Newburgh ECSD

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195451-1  
SDG Number: South Jr High- Newburgh ECSD

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195451-1  
SDG Number: South Jr High- Newburgh ECSD

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195451-1	Kitchen KS #1	Drinking Water	04/13/2021 0430	04/15/2021 1212
420-195451-2	Kitchen KS #2	Drinking Water	04/13/2021 0430	04/15/2021 1212
420-195451-3	Kitchen KS #3	Drinking Water	04/13/2021 0431	04/15/2021 1212
420-195451-4	Kitchen KSP	Drinking Water	04/13/2021 0432	04/15/2021 1212
420-195451-5	Kitchen HS	Drinking Water	04/13/2021 0433	04/15/2021 1212
420-195451-6	Kitchen KF	Drinking Water	04/13/2021 0433	04/15/2021 1212
420-195451-7	Kitchen BS	Drinking Water	04/13/2021 0434	04/15/2021 1212
420-195451-8	Cafe BF	Drinking Water	04/13/2021 0436	04/15/2021 1212
420-195451-9	Cafe Boys BS #1	Drinking Water	04/13/2021 0437	04/15/2021 1212
420-195451-10	Cafe Boys BS #2	Drinking Water	04/13/2021 0437	04/15/2021 1212
420-195451-11	Cafe Girls BS #2	Drinking Water	04/13/2021 0438	04/15/2021 1212
420-195451-12	O/S Girls Gym BF	Drinking Water	04/13/2021 0439	04/15/2021 1212
420-195451-13	Girls Gym Office BS	Drinking Water	04/13/2021 0440	04/15/2021 1212
420-195451-14	Girls Gym Locker Room BS	Drinking Water	04/13/2021 0442	04/15/2021 1212
420-195451-15	1st Floor Faculty BF	Drinking Water	04/13/2021 0443	04/15/2021 1212
420-195451-16	1st Floor Faculty Right BS #2	Drinking Water	04/13/2021 0444	04/15/2021 1212
420-195451-17	1st Floor Faculty BS #1	Drinking Water	04/13/2021 0445	04/15/2021 1212
420-195451-18	Dance Studio CS#1	Drinking Water	04/13/2021 0446	04/15/2021 1212
420-195451-19	Dance Studio CS#2	Drinking Water	04/13/2021 0447	04/15/2021 1212
420-195451-20	O/S Technology BF	Drinking Water	04/13/2021 0448	04/15/2021 1212
420-195451-21	RM L13 SS	Drinking Water	04/13/2021 0449	04/15/2021 1212
420-195451-22	RM L12 CS#1	Drinking Water	04/13/2021 0450	04/15/2021 1212
420-195451-23	L12 CS #2	Drinking Water	04/13/2021 0450	04/15/2021 1212
420-195451-24	L12 CS #3	Drinking Water	04/13/2021 0450	04/15/2021 1212
420-195451-25	L11 BS	Drinking Water	04/13/2021 0452	04/15/2021 1212
420-195451-26	L11 CS	Drinking Water	04/13/2021 0453	04/15/2021 1212
420-195451-27	RM 100 BS #1	Drinking Water	04/13/2021 0457	04/15/2021 1212
420-195451-28	RM 100 BS #2	Drinking Water	04/13/2021 0457	04/15/2021 1212
420-195451-29	RM 100 BS #3	Drinking Water	04/13/2021 0458	04/15/2021 1212
420-195451-30	RM 100 BS #4	Drinking Water	04/13/2021 0458	04/15/2021 1212
420-195451-31	Boys Gym BF	Drinking Water	04/13/2021 0500	04/15/2021 1212
420-195451-32	Boys Gym Office BS	Drinking Water	04/13/2021 0501	04/15/2021 1212
420-195451-33	O/S Rm 105 BS #1	Drinking Water	04/13/2021 0502	04/15/2021 1212
420-195451-34	O/S Rm 105 BS #2	Drinking Water	04/13/2021 0502	04/15/2021 1212
420-195451-35	O/S Rm 107 BF	Drinking Water	04/13/2021 0504	04/15/2021 1212
420-195451-36	O/S Rm 111 Boys BS #1	Drinking Water	04/13/2021 0506	04/15/2021 1212
420-195451-37	O/S Rm 111 Boys BS #2	Drinking Water	04/13/2021 0506	04/15/2021 1212
420-195451-38	O/S Library BF	Drinking Water	04/13/2021 0507	04/15/2021 1212
420-195451-39	Library CS #1	Drinking Water	04/13/2021 0509	04/15/2021 1212
420-195451-40	Library/ Faculty CS #2	Drinking Water	04/13/2021 0509	04/15/2021 1212
420-195451-41	Lobby BF	Drinking Water	04/13/2021 0540	04/15/2021 1212
420-195451-42	Principal's Office BS	Drinking Water	04/13/2021 0512	04/15/2021 1212
420-195451-43	Main Office BS	Drinking Water	04/13/2021 0512	04/15/2021 1212
420-195451-44	Copy Room BS	Drinking Water	04/13/2021 0513	04/15/2021 1212
420-195451-45	Health Office CS	Drinking Water	04/13/2021 0516	04/15/2021 1212

## SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195451-1  
SDG Number: South Jr High- Newburgh ECSD

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195451-46	Health Office BS	Drinking Water	04/13/2021 0516	04/15/2021 1212
420-195451-47	O/S Rm 213 BF	Drinking Water	04/13/2021 0519	04/15/2021 1212
420-195451-48	3rd Floor Faculty BS #1	Drinking Water	04/13/2021 0520	04/15/2021 1212
420-195451-49	3rd Floor Faculty BS #2	Drinking Water	04/13/2021 0520	04/15/2021 1212
420-195451-50	Rm Save BS	Drinking Water	04/13/2021 0522	04/15/2021 1212
420-195451-51	4th Floor Girls BS #1	Drinking Water	04/13/2021 0523	04/15/2021 1212
420-195451-52	4th Floor Girls BS #2	Drinking Water	04/13/2021 0524	04/15/2021 1212
420-195451-53	O/S Rm 206 BF	Drinking Water	04/13/2021 0525	04/15/2021 1212
420-195451-54	Rm 204 KS #1	Drinking Water	04/13/2021 0528	04/15/2021 1212
420-195451-55	Rm 204 KS #2	Drinking Water	04/13/2021 0528	04/15/2021 1212
420-195451-56	Rm 204 KS #3	Drinking Water	04/13/2021 0529	04/15/2021 1212
420-195451-57	Rm 204 KS #4	Drinking Water	04/13/2021 0529	04/15/2021 1212
420-195451-58	4th Floor Boys BS #1	Drinking Water	04/13/2021 0531	04/15/2021 1212
420-195451-59	4th Floor Boys BS #2	Drinking Water	04/13/2021 0531	04/15/2021 1212
420-195451-60	3rd Floor Boys BS #2	Drinking Water	04/13/2021 0534	04/15/2021 1212
420-195451-61	O/S Rm 218 BF	Drinking Water	04/13/2021 0537	04/15/2021 1212
420-195451-62	3rd Floor Girls BS #1	Drinking Water	04/13/2021 0538	04/15/2021 1212
420-195451-63	3rd Floor Girls BS #2	Drinking Water	04/13/2021 0538	04/15/2021 1212
420-195451-64	O/S Rm 221 BF	Drinking Water	04/13/2021 0539	04/15/2021 1212
420-195451-65	O/S Rm 119A BS Faculty	Drinking Water	04/13/2021 0542	04/15/2021 1212
420-195451-66	O/S Rm 119A BF	Drinking Water	04/13/2021 0543	04/15/2021 1212
420-195451-67	O/S Rm 119 Girls BS #1	Drinking Water	04/13/2021 0544	04/15/2021 1212
420-195451-68	O/S Rm 119 Girls BS #2	Drinking Water	04/13/2021 0544	04/15/2021 1212
420-195451-69	Rm 121 CS	Drinking Water	04/13/2021 0545	04/15/2021 1212
420-195451-70	O/S Rm 122 BF	Drinking Water	04/13/2021 0546	04/15/2021 1212

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen KS #1  
**Lab Sample ID:** 420-195451-1

Date Sampled: 04/13/2021 0430  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0226	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen KS #2  
**Lab Sample ID:** 420-195451-2

Date Sampled: 04/13/2021 0430  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0149	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen KS #3  
**Lab Sample ID:** 420-195451-3

Date Sampled: 04/13/2021 0431  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0151	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	42.2 g	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen KSP  
**Lab Sample ID:** 420-195451-4

Date Sampled: 04/13/2021 0432  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0153	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen HS  
**Lab Sample ID:** 420-195451-5

Date Sampled: 04/13/2021 0433  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0155	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	12.3	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen KF  
**Lab Sample ID:** 420-195451-6

Date Sampled: 04/13/2021 0433  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0157	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Kitchen BS  
**Lab Sample ID:** 420-195451-7

Date Sampled: 04/13/2021 0434  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0200	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	7.82	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Cafe BF  
**Lab Sample ID:** 420-195451-8

Date Sampled: 04/13/2021 0436  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0206	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Cafe Boys BS #1  
**Lab Sample ID:** 420-195451-9

Date Sampled: 04/13/2021 0437  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0208	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Cafe Boys BS #2  
**Lab Sample ID:** 420-195451-10

Date Sampled: 04/13/2021 0437  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0211	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Cafe Girls BS #2  
**Lab Sample ID:** 420-195451-11

Date Sampled: 04/13/2021 0438  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0213	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Girls Gym BF  
**Lab Sample ID:** 420-195451-12

Date Sampled: 04/13/2021 0439  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0222	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Girls Gym Office BS  
**Lab Sample ID:** 420-195451-13

Date Sampled: 04/13/2021 0440  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0224	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	54.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Girls Gym Locker Room BS  
**Lab Sample ID:** 420-195451-14

Date Sampled: 04/13/2021 0442  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0232	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.14	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 1st Floor Faculty BF  
**Lab Sample ID:** 420-195451-15

Date Sampled: 04/13/2021 0443  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0235	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 1st Floor Faculty Right BS #2  
**Lab Sample ID:** 420-195451-16

Date Sampled: 04/13/2021 0444  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0237	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	12.5	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 1st Floor Faculty BS #1  
**Lab Sample ID:** 420-195451-17

Date Sampled: 04/13/2021 0445  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0239	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.59	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Dance Studio CS#1  
**Lab Sample ID:** 420-195451-18

Date Sampled: 04/13/2021 0446  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0241	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	7.89	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Dance Studio CS#2  
**Lab Sample ID:** 420-195451-19

Date Sampled: 04/13/2021 0447  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0243	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	6.19	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Technology BF  
**Lab Sample ID:** 420-195451-20

Date Sampled: 04/13/2021 0448  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/16/2021	0246	
Prep Method: 200.7/200.8			Date Prepared: 06/08/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** RM L13 SS  
**Lab Sample ID:** 420-195451-21

Date Sampled: 04/13/2021 0449  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0248	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	41.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** RM L12 CS#1  
**Lab Sample ID:** 420-195451-22

Date Sampled: 04/13/2021 0450  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0252	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	47.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** L12 CS #2  
**Lab Sample ID:** 420-195451-23

Date Sampled: 04/13/2021 0450  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0259	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	156 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** L12 CS #3  
**Lab Sample ID:** 420-195451-24

Date Sampled: 04/13/2021 0450  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0301	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	17.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** L11 BS  
**Lab Sample ID:** 420-195451-25

Date Sampled: 04/13/2021 0452  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0303	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** L11 CS  
**Lab Sample ID:** 420-195451-26

Date Sampled: 04/13/2021 0453  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0305	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.11	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** RM 100 BS #1  
**Lab Sample ID:** 420-195451-27

Date Sampled: 04/13/2021 0457  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0307	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID: RM 100 BS #2**  
**Lab Sample ID: 420-195451-28**

Date Sampled: 04/13/2021 0457  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/16/2021	0310	
Prep Method: 200.7/200.8			Date Prepared: 06/08/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID: RM 100 BS #3**  
**Lab Sample ID: 420-195451-29**

Date Sampled: 04/13/2021 0458  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/16/2021 0312	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.22	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID: RM 100 BS #4**  
**Lab Sample ID: 420-195451-30**

Date Sampled: 04/13/2021 0458  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 06/16/2021	0314	
Prep Method: 200.7/200.8			Date Prepared: 06/08/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Boys Gym BF  
**Lab Sample ID:** 420-195451-31

Date Sampled: 04/13/2021 0500  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1146	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Boys Gym Office BS  
**Lab Sample ID:** 420-195451-32

Date Sampled: 04/13/2021 0501  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/17/2021 1519	
Prep Method: 200.7/200.8			Date Prepared:	06/09/2021 1350	
Pb	174	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 105 BS #1  
**Lab Sample ID:** 420-195451-33

Date Sampled: 04/13/2021 0502  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1159	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 105 BS #2  
**Lab Sample ID:** 420-195451-34

Date Sampled: 04/13/2021 0502  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1201	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.40	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 107 BF  
**Lab Sample ID:** 420-195451-35

Date Sampled: 04/13/2021 0504  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1203	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 111 Boys BS #1  
**Lab Sample ID:** 420-195451-36

Date Sampled: 04/13/2021 0506  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1206	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 111 Boys BS #2  
**Lab Sample ID:** 420-195451-37

Date Sampled: 04/13/2021 0506  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1208	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Library BF  
**Lab Sample ID:** 420-195451-38

Date Sampled: 04/13/2021 0507  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1210	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Library CS #1  
**Lab Sample ID:** 420-195451-39

Date Sampled: 04/13/2021 0509  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1212	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Library/ Faculty CS #2  
**Lab Sample ID:** 420-195451-40

Date Sampled: 04/13/2021 0509  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1214	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.91	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Lobby BF  
**Lab Sample ID:** 420-195451-41

Date Sampled: 04/13/2021 0540  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1221	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Principal's Office BS  
**Lab Sample ID:** 420-195451-42

Date Sampled: 04/13/2021 0512  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1225	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.15	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Main Office BS  
**Lab Sample ID:** 420-195451-43

Date Sampled: 04/13/2021 0512  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1227	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.84	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID: Copy Room BS**  
**Lab Sample ID: 420-195451-44**

Date Sampled: 04/13/2021 0513  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1230	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.68	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Health Office CS  
**Lab Sample ID:** 420-195451-45

Date Sampled: 04/13/2021 0516  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1232	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.59	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Health Office BS  
**Lab Sample ID:** 420-195451-46

Date Sampled: 04/13/2021 0516  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1234	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.98	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 213 BF  
**Lab Sample ID:** 420-195451-47

Date Sampled: 04/13/2021 0519  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1236	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 3rd Floor Faculty BS #1  
**Lab Sample ID:** 420-195451-48

Date Sampled: 04/13/2021 0520  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1238	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 3rd Floor Faculty BS #2  
**Lab Sample ID:** 420-195451-49

Date Sampled: 04/13/2021 0520  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1241	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm Save BS  
**Lab Sample ID:** 420-195451-50

Date Sampled: 04/13/2021 0522  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1247	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 4th Floor Girls BS #1  
**Lab Sample ID:** 420-195451-51

Date Sampled: 04/13/2021 0523  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1249	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 4th Floor Girls BS #2  
**Lab Sample ID:** 420-195451-52

Date Sampled: 04/13/2021 0524  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1251	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 206 BF  
**Lab Sample ID:** 420-195451-53

Date Sampled: 04/13/2021 0525  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1300	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm 204 KS #1  
**Lab Sample ID:** 420-195451-54

Date Sampled: 04/13/2021 0528  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1302	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	31.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm 204 KS #2  
**Lab Sample ID:** 420-195451-55

Date Sampled: 04/13/2021 0528  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1305	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.41	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm 204 KS #3  
**Lab Sample ID:** 420-195451-56

Date Sampled: 04/13/2021 0529  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1307	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.66	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm 204 KS #4  
**Lab Sample ID:** 420-195451-57

Date Sampled: 04/13/2021 0529  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1313	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.93	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 4th Floor Boys BS #1  
**Lab Sample ID:** 420-195451-58

Date Sampled: 04/13/2021 0531  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1316	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 4th Floor Boys BS #2  
**Lab Sample ID:** 420-195451-59

Date Sampled: 04/13/2021 0531  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1318	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 3rd Floor Boys BS #2  
**Lab Sample ID:** 420-195451-60

Date Sampled: 04/13/2021 0534  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1320	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 218 BF  
**Lab Sample ID:** 420-195451-61

Date Sampled: 04/13/2021 0537  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1322	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 3rd Floor Girls BS #1  
**Lab Sample ID:** 420-195451-62

Date Sampled: 04/13/2021 0538  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1324	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** 3rd Floor Girls BS #2  
**Lab Sample ID:** 420-195451-63

Date Sampled: 04/13/2021 0538  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1329	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.16	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 221 BF  
**Lab Sample ID:** 420-195451-64

Date Sampled: 04/13/2021 0539  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1331	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 119A BS Faculty  
**Lab Sample ID:** 420-195451-65

Date Sampled: 04/13/2021 0542  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1333	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 119A BF  
**Lab Sample ID:** 420-195451-66

Date Sampled: 04/13/2021 0543  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1340	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 119 Girls BS #1  
**Lab Sample ID:** 420-195451-67

Date Sampled: 04/13/2021 0544  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1342	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0



Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 119 Girls BS #2  
**Lab Sample ID:** 420-195451-68

Date Sampled: 04/13/2021 0544  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1344	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.06	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** Rm 121 CS  
**Lab Sample ID:** 420-195451-69

Date Sampled: 04/13/2021 0545  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1346	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	101 g	ug/L	1.00	1.00	1.0

Jack DeGraw  
Orange-Ulster BOCES  
53 Gibson Road  
Goshen, NY 10924

Job Number: 420-195451-1  
Sdg Number: South Jr High- Newburgh ECSD

**Client Sample ID:** O/S Rm 122 BF  
**Lab Sample ID:** 420-195451-70

Date Sampled: 04/13/2021 0546  
Date Received: 04/15/2021 1212  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1348	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

## DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:  
Sdg Number: South Jr High- Newburgh ECSD

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: South Jr High- Newburgh ECSD

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

## Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: South Jr High- Newburgh ECSD

---

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points







**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: <b>195451</b> <b>3 FS</b>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		<b>Analysis Requested</b>			Page: Page 1 of 1																						
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	<table border="1"> <tr> <td>Field Filtered Sample (Yes or No)</td> <td>Perform MS/MSD (Yes or No)</td> <td>Chlorine Present (Yes or No)</td> <td>Lead</td> <td rowspan="5">Total Number of Containers</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> </table>			Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers																	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)				Lead	Total Number of Containers																				
City: Goshen		TAT Requested (days):																									
State, Zip: NY, 10924		PO #:																									
Phone: 845-781-4887		PWS #:																									
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:																									
Project Name: Newburgh ECSD		Additional Contacts:																									
Site: South Jr High					Other: <b>D-Nitric Acid</b> Upon Receipt Preservation verified: Y / N																						

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/13/21	500	BOYS GYM BF		G	DW				1	1	
4/13/21	501	BOYS GYM OFFICE BS		G	DW				1	1	
4/13/21	502	O/S RM 105 BS #1		G	DW				1	1	
4/13/21	502	O/S RM 105BS #2		G	DW				1	1	
4/13/21	504	O/S RM 107 BF		G	DW				1	1	
4/13/21	506	O/S RM 111 BOYS BS #1		G	DW				1	1	
4/13/21	506	O/S RM 111 BOYS BS #2		G	DW				1	1	
4/13/21	507	O/S LIBRARY BF		G	DW				1	1	
4/13/21	509	LIBRARY CS #1		G	DW				1	1	
4/13/21	509	LIBRARY/FACULTY CS #2		G	DW				1	1	
4/13/21	540	LOBBY BF		G	DW				1	1	
4/13/21	512	PRINCIPALS OFFICE BS		G	DW				1	1	
4/13/21	512	MAIN OFFICE BS		G	DW				1	1	
4/13/21	513	COPY ROOM BS		G	DW				1	1	
4/13/21	516	HEALTHY OFFICE CS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 4/15/21 12:12	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 4/15/21 12:12	Company: <i>[Signature]</i>
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present:  Custody Seal No.: \_\_\_\_\_ Custody Seals Intact:  Cooler Temperature(s) °C/IR GUN #: 20.0 °C





## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-195451-1  
SDG Number: South Jr High- Newburgh ECSD

**Login Number: 195451**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	