

April 11, 2024

Maureen Doherty
NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Project Location: Heritage
Project Number: Newburgh ECSD
Laboratory Work Order Number: 24C2915

Enclosed are results of analyses for samples received by the laboratory on March 26, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



NB-Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924
ATTN: Maureen Doherty

REPORT DATE: 4/11/2024

PURCHASE ORDER NUMBER: A24-00300

PROJECT NUMBER: Newburgh ECSD

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24C2915

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Heritage

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
Kitchen - Sink across managers office	24C2915-01	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen -middle KS2	24C2915-02	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen -middle KS6	24C2915-03	Drinking Water		EPA 200.8 Rev 5.4	
Kitchen - Kettle	24C2915-04	Drinking Water		EPA 200.8 Rev 5.4	
Cafe BF	24C2915-05	Drinking Water		EPA 200.8 Rev 5.4	
Gym Area DF# 1	24C2915-06	Drinking Water		EPA 200.8 Rev 5.4	
Gym AreaBF# 2	24C2915-07	Drinking Water		EPA 200.8 Rev 5.4	
Gym Area DF# 2	24C2915-08	Drinking Water		EPA 200.8 Rev 5.4	
4th Floor next to Rm 402 BF	24C2915-09	Drinking Water		EPA 200.8 Rev 5.4	
4th Floor next to Rm 402 DF	24C2915-10	Drinking Water		EPA 200.8 Rev 5.4	
3rd Floor across Rm 309 BF	24C2915-11	Drinking Water		EPA 200.8 Rev 5.4	
3rd Floor across Rm 309 DF	24C2915-12	Drinking Water		EPA 200.8 Rev 5.4	
3rd floor near 3A BF	24C2915-13	Drinking Water		EPA 200.8 Rev 5.4	
3rd floor near 3A DF	24C2915-14	Drinking Water		EPA 200.8 Rev 5.4	
3rd floor 3A	24C2915-15	Drinking Water		EPA 200.8 Rev 5.4	
Rm 202 CS # 1	24C2915-16	Drinking Water		EPA 200.8 Rev 5.4	
Rm 202 CS # 2	24C2915-17	Drinking Water		EPA 200.8 Rev 5.4	
Rm 202 CS # 3	24C2915-18	Drinking Water		EPA 200.8 Rev 5.4	
2nd floor staff 2B	24C2915-19	Drinking Water		EPA 200.8 Rev 5.4	
2nd floor DF (b Side)	24C2915-20	Drinking Water		EPA 200.8 Rev 5.4	
2nd floor BF (a Side)	24C2915-21	Drinking Water		EPA 200.8 Rev 5.4	
2nd floor DF (a Side)	24C2915-22	Drinking Water		EPA 200.8 Rev 5.4	
Rm 213 CS # 1	24C2915-23	Drinking Water		EPA 200.8 Rev 5.4	
Rm 213 CS # 2	24C2915-24	Drinking Water		EPA 200.8 Rev 5.4	
Rm 213 CS # 3	24C2915-25	Drinking Water		EPA 200.8 Rev 5.4	
Health Office NS	24C2915-26	Drinking Water		EPA 200.8 Rev 5.4	
1st Floor staff Rm 1B CS	24C2915-27	Drinking Water		EPA 200.8 Rev 5.4	
Next to girls 1B BF 1st Floor	24C2915-28	Drinking Water		EPA 200.8 Rev 5.4	
Next to girls 1B DF 1st Floor	24C2915-29	Drinking Water		EPA 200.8 Rev 5.4	
Next to staff 1A BF 1st Floor	24C2915-30	Drinking Water		EPA 200.8 Rev 5.4	
Next to staff 1A DF 1st Floor	24C2915-31	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Felicia Morgan-Nichols
Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Kitchen - Sink across managers office

Sampled: 3/26/2024 07:17

Sample ID: 24C2915-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:17	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Kitchen -middle KS2

Sampled: 3/26/2024 07:18

Sample ID: 24C2915-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Kitchen -middle KS6

Sampled: 3/26/2024 07:18

Sample ID: 24C2915-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:26	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Kitchen - Kettle

Sampled: 3/26/2024 07:19

Sample ID: 24C2915-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Sampled: 3/26/2024 07:21

Field Sample #: Cafe BF

Sample ID: 24C2915-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Gym Area DF# 1

Sampled: 3/26/2024 07:24

Sample ID: 24C2915-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Gym AreaBF# 2

Sampled: 3/26/2024 07:25

Sample ID: 24C2915-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:38	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Gym Area DF# 2

Sampled: 3/26/2024 07:25

Sample ID: 24C2915-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 4th Floor next to Rm 402 BF

Sampled: 3/26/2024 07:30

Sample ID: 24C2915-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 13:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 4th Floor next to Rm 402 DF

Sampled: 3/26/2024 07:31

Sample ID: 24C2915-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:42	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 3rd Floor across Rm 309 BF

Sampled: 3/26/2024 07:36

Sample ID: 24C2915-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 3rd Floor across Rm 309 DF

Sampled: 3/26/2024 07:36

Sample ID: 24C2915-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:46	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 3rd floor near 3A BF

Sampled: 3/26/2024 07:33

Sample ID: 24C2915-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:49	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 3rd floor near 3A DF

Sampled: 3/26/2024 07:33

Sample ID: 24C2915-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:51	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 3rd floor 3A

Sampled: 3/26/2024 07:39

Sample ID: 24C2915-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 202 CS # 1

Sampled: 3/26/2024 07:51

Sample ID: 24C2915-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 18:59	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 202 CS # 2

Sampled: 3/26/2024 07:51

Sample ID: 24C2915-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:01	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 202 CS # 3

Sampled: 3/26/2024 07:51

Sample ID: 24C2915-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:03	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 2nd floor staff 2B

Sampled: 3/26/2024 07:50

Sample ID: 24C2915-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:05	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 2nd floor DF (b Side)

Sampled: 3/26/2024 07:48

Sample ID: 24C2915-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:07	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 2nd floor BF (a Side)

Sampled: 3/26/2024 07:46

Sample ID: 24C2915-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:09	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 2nd floor DF (a Side)

Sampled: 3/26/2024 07:46

Sample ID: 24C2915-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:11	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 213 CS # 1

Sampled: 3/26/2024 07:42

Sample ID: 24C2915-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:22	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 213 CS # 2

Sampled: 3/26/2024 07:43

Sample ID: 24C2915-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Rm 213 CS # 3

Sampled: 3/26/2024 07:43

Sample ID: 24C2915-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:26	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Health Office NS

Sampled: 3/26/2024 07:59

Sample ID: 24C2915-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: 1st Floor staff Rm 1B CS

Sampled: 3/26/2024 07:58

Sample ID: 24C2915-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	1.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:30	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Next to girls 1B BF 1st Floor

Sampled: 3/26/2024 07:57

Sample ID: 24C2915-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:32	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Next to girls 1B DF 1st Floor

Sampled: 3/26/2024 07:56

Sample ID: 24C2915-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Next to staff 1A BF 1st Floor

Sampled: 3/26/2024 07:55

Sample ID: 24C2915-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: Heritage

Sample Description:

Work Order: 24C2915

Date Received: 3/26/2024

Field Sample #: Next to staff 1A DF 1st Floor

Sampled: 3/26/2024 07:57

Sample ID: 24C2915-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/2/24	4/4/24 19:37	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024

Pace® Newburgh, NY

Location Requested (City/State):

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-custody is a LEGAL DOCUMENT - complete all relevant fields

Company Name: Orange-Ulster BOCES
 Street Address: 53 Gibson Road
 Goshen, NY 10924
 Contact/Report to: Maureen Doherty
 Phone #: 845-781-4887
 E-Mail: Maureen.Doherty@oubooces.org
 CC E-Mail: Halina.redner@oubooces.org
 Customer Project #: Invoice to: Halina Redner
 Invoice E-mail: halina.redner@oubooces.org
 Purchase Order # (if applicable): A24-00300
 Quote #:

Project Name: Newburgh ECSS
 Site Collection Info/Facility ID (as applicable):
Heritage
 Time Zone Collected: [] AK [] PT [] MT [] CT ET
 County/State origin of sample(s): Orange County / New York
 Data Deliverables: [] Level II [] Level III [] Level IV
 Regulatory Program (DW, RCRA, etc.) as applicable: DOH
 Rush (Pre-approval required):
 [] Same Day [] 1 Day [] 2 Day [] 3 Day Other _____
 Date Results: _____
 Requested: _____
 Analysis: _____
 Field Filtered (if applicable): [] Yes No
 Reportable Yes [] No
 DW PWSID # or VW Permit # as applicable: _____
 *Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (TS), Biossary (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Sank (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Match *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
Kitchen-sink across managers office	DW	G			3/26	7:17			
Kitchen-middle KS2	DW	G			3/26	7:18			
Kitchen-middle KS6	DW	G			3/26	7:19			
Kitchen-Kettle	DW	G			3/26	7:21			
Cafe BF	DW	G							
Cafe-DF	DW	G							
Gym Area BE # 1	DW	G			3/26	7:24			
Gym Area DF # 1	DW	G			3/26	7:25			
Gym Area BF # 2	DW	G			3/26	7:25			
Gym Area DF # 2	DW	G			3/26	7:25			

Additional Instructions from Pace®:
 Collected By: Bryan Welsh
 Printed Name: _____
 Signature: _____

Reinquished by/Company: (Signature) _____ Date/Time: 3/26/24 12:15
 Received by/Company: (Signature) _____ Date/Time: 3/26/24 12:22
 Reinquished by/Company: (Signature) _____ Date/Time: _____
 Received by/Company: (Signature) _____ Date/Time: _____



LAB USE ONLY - Affix Workorder/Login Label Here
24C2915
 Scan QR Code for instructions

Specify Container Size: **
 (4) 125mL, (5) 100mL, (6) 40mL, Vial, (7) Encore, (8) Petri-dish, (9) 50mL, (10) Other
 Identify Container Preservation Type: **
 Analysis Requested:
 Preserve non-conformance identified for sample.

Lab Use Only
 Project Manager: _____
 ActNum / Client ID: _____
 Table #: _____
 Profile / Template: _____
 Prepog / Bottle Ord. ID: _____
 Sample Comment: _____

Customer Remarks / Special Conditions / Possible Hazards:
 # Codes: _____
 Thermometer ID: _____ Correction Factor (°C): _____ Obs. Temp. (°C): _____
 Corrected Temp. (°C): _____ [] On Ice
 Tracking Number: _____
 Delivered by: [] In-Person [] Courier
 [] FedEx [] UPS [] Other
 Page: 1 of 4



Pace® Location Requested (City/State):

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES
 Street Address: 53 Gibson Road
 Goshen, NY 10924
 Contact/Report to: Maureen Doherty
 Phone #: 845-781-4887
 E-Mail: Maureen.Doherty@oubooces.org
 CC E-Mail: Halina.redner@oubooces.org

Project Name: Newburgh EGSS
 Site Collection Info/Facility ID (as applicable):
 Heritage
 Regulatory Program (DW, RCRA, etc.) as applicable: DW
 Reportable: Yes No
 County / State origin of sample(s): Orange County / New York

Time Zones Collected: AK PT MT CT ET
 Data Deliverables:
 Level II Level III Level IV
 EQUUS
 Other: _____
 Rush (Pre-approval required):
 Same Day 1 Day 2 Day 3 Day Other _____
 Date Results Requested: _____
 Analysis: Field Filtered (if applicable): Yes No

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Gull (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start Date	Time	Collected or Composite End Date	Time	# Cont.	Residual Chlorine Result	Units
4th Floor next to Rm 402 BF	DW	G	3/26	7:30	3/26	7:30	X		
4th Floor next to Rm 402 DF	DW	G	3/26	7:31	3/26	7:31	X		
3rd Floor across Rm 309 BF	DW	G	3/26	7:36	3/26	7:36	X		
3rd Floor across Rm 309 DF	DW	G	3/26	7:36	3/26	7:36	X		
3rd floor near 3A BF	DW	G	3/26	7:33	3/26	7:33	X		
3rd floor near 3A DF	DW	G	3/26	7:33	3/26	7:33	X		
3rd floor 3A	DW	G	3/26	7:39	3/26	7:39	X		
Rm 202 CS # 1	DW	G	3/26	7:51	3/26	7:51	X		
Rm 202 CS # 2	DW	G	3/26	7:51	3/26	7:51	X		
Rm 202 CS # 3	DW	G	3/26	7:51	3/26	7:51	X		

Additional Instructions from Pace®:
 Collected By: *Bryan Wells*
 Printed Name: Bryan Wells
 Signature: *[Signature]*

Relinquished by/Company (Signature): *[Signature]* Date/Time: 3/26/24 12:15
 Relinquished by/Company (Signature): *[Signature]* Date/Time: 3/26/24 16:00
 Relinquished by/Company (Signature): *[Signature]* Date/Time: _____
 Relinquished by/Company (Signature): *[Signature]* Date/Time: _____



LAB USE ONLY - Attach Workorder/Login Label Here
 24C2915
 Scan QR Code for instructions

Specify container size: (4) 125mL, (5) 100mL, (6) 20mL, (7) 15mL, (8) 10mL, (9) 5mL, (10) Other
 Identify container Preservative Type: None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sulf, (9) Ascorbic Acid, (10) MeOH, (11) Other
 Analysis Requested: _____

Lead Testing
 Prof. Mgr.: _____
 Acticum / Client ID: _____
 Table #: _____
 Profile / Template: _____
 Prelog / Bottle Ord. ID: _____
 Sample Comment: _____
 Preservation non-conformance identified for sample: _____

Customer Remarks / Special Conditions / Possible Hazards:
 # Coolers: _____ Thermometer ID: _____ Correction Factor (°C): _____ Obs. Temp. (°C): _____
 Tracking Number: _____
 Delivered by: In-Person Courier FedEx UPS Other
 Page: 2 of 4

Pace® Location Requested (City/State): **CHAIN-OF-CUSTODY Analytical Request Document**

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES
 Street Address: 53 Gibson Road
 Goshen, NY 10924
 Contact/Report To: Maureen Doherty
 Phone #: 845-781-4887
 E-Mail: Maureen.Doherty@oubooces.org
 CC E-Mail: Halina.redner@oubooces.org

Customer Project #: **Heritage**
 Project Name: Newnapi ESDS
 Site Collection Info/Facility ID (as applicable):
 Invoice E-mail: halina.redner@oubooces.org
 Purchase Order # (if applicable): A24-00300
 Quote #:

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET
 County / State origin of sample(s): Orange County / New York
 Data Deliverables: [] Level II [] Level III [] Level IV
 Regulatory Program (DW, RCRA, etc.) as applicable: DW PWSID # or WW Permit # as applicable: Yes [] No
 DOH: Rush (Pre-approval required): Same Day [] 1 Day [] 2 Day [] 3 Day Other _____
 [] EQUS Date Results: _____
 [] Other: _____
 Analysis: Field Filtered (if applicable): [] Yes No

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GM), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cank (CK), Leachate (L), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start		Collected or Composite End		# Cont.	Residual Chlorine Result	Units
			Date	Time	Date	Time			
21 2nd floor staff 2B	DW	G	3/26		750				
22 2nd floor BF (b side)	DW	G	3/26		748				
23 2nd floor DF (b side)	DW	G	3/26		746				
24 2nd floor BF (a side)	DW	G	3/26		746				
25 2nd floor DF (a side)	DW	G	3/26		742				
26 Rm 213 CS # 1	DW	G	3/26		743				
27 Rm 213 CS # 2	DW	G	3/26		743				
28 Rm 213 CS # 3	DW	G	3/26		759				
29 Health Office NS	DW	G	3/26		758				
30 1st floor staff Rm 1B CS	DW	G	3/26						

Collected By: **Bryon Weiss**
 Printed Name: _____
 Signature: _____

Relinquished by/Company: (Signature) _____ Date/Time: 3/26/24 12:18
 Relinquished by/Company: (Signature) _____ Date/Time: _____
 Relinquished by/Company: (Signature) _____ Date/Time: _____
 Relinquished by/Company: (Signature) _____ Date/Time: _____



LAB USE ONLY: Affix Workorder/Login Label Here
 Scan QR Code for instructions
24CC2915

Specify Container Size**	Identify Container Preservation Type***	Analysis Requested
3		
2		

Lead Testing	Proj. Mgr:	ActNum / Client ID:	Table #:	Profile / Template:	Presg / Bottle Ord. ID:	Sample Comment

Customer Remarks / Special Conditions / Possible Hazards: _____
 # Codes: _____
 Thermometer ID: _____ Correction Factor (°C): _____ Obs. Temp. (°C): _____ Corrected Temp. (°C): _____
 Date/Time: 3/26/24 12:22
 Tracking Number: _____
 Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other
 Page: **3** of **4**

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Orange-Ulster BOCES
 Street Address:
 53 Gibson Road
 Goshen, NY 10924

Contact/Report to: Maureen Doherty
 Phone #: 845-781-4887
 E-Mail: Maureen.Doherty@outboxes.org
 CC E-Mail: Halina.redner@outboxes.org

Customer Project #:

Invoice E-mail:
 halina.redner@outboxes.org

Project Name:
 Newburgh ESCO

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable): A24-00300

Heritage

Quote #:

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET

County / State origin of sample(s): Orange County / New York

Data Deliverables: [] Level II [] Level III [] Level IV [] Level V

Reportable: Yes [] No

[] Level II [] Level III [] Level IV

DW PW/SID # or WW Permit # as applicable:

[] EQUS

Field Filtered (if applicable): [] Yes No

[] Other

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (TS), Biosessy (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Cank (CK), Leachate (L), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab	Composite Start		Collected or Composite End		# Cont.	Residual Chlorine Result	Units
			Date	Time	Date	Time			
31	Next to girls 1B BF 1st Floor	DW	G		3/26	7:57			X
32	Next to girls 1B DF 1st Floor	DW	G		3/26	7:56			X
33	Next to staff 1A BF 1st floor	DW	G		3/26	7:55			X
34	Next to staff 1A DF 1st floor	DW	G		3/26	7:57			X
		DW	G						X
		DW	G						X
		DW	G						X
		DW	G						X
		DW	G						X
		DW	G						X

Additional instructions from Pace®:

Collected by: *Bryon Welsh*
 Printed Name
 Signature

Relinquished by/Company (Signature)	Date/Time	Received by/Company (Signature)	Date/Time
<i>Maureen Doherty</i>	3/26/24 12:18	<i>Bryon Welsh</i>	
<i>Maureen Doherty</i>		<i>Maureen Doherty</i>	
<i>Maureen Doherty</i>		<i>Maureen Doherty</i>	



LAB USE ONLY - Affix Workorder/LogIn Label Here
 Scan QR Code for instructions
 24C2915

Identify Container Preservative Type***	Analysis Requested
3	
2	

Lead Testing

Thermometer ID:	Correction Factor (°C):	Obs. Temp. (°C):	Corrected Temp. (°C):	On Ice

Trade Number:	Delivered by:	In-Person	Courier
		<input type="checkbox"/>	<input type="checkbox"/>

Sample Condition Upon Receipt Form (SCUR)

Project # 24C2915
 Client: DuBois
Heritage

Date and Initials of person:
 Examining contents: _____
 Label: _____
 Deliver to location: Bloomington
 pH: _____

Thermometer Used: _____ Date: 3/26/24 Time: 12:22 Initials: JE

State of Origin: NY

Cooler #1 Temp. °C _____ (Visual) _____ (Correction Factor) _____ (Actual) Samples on ice, cooling process has begun

Courier: Fed Ex UPS USPS Client Commercial Pace Other _____

Shipping Method: First Overnight Priority Overnight Standard Overnight Ground Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Ice: Wet Blue Melted None

Packing Material: Bubble Wrap Bubble Bags None Other _____

Samples were collected by Pace employee Yes No N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Additional Login Comments:

Client notification/ Resolution
 Person Contacted: _____ Date/Time: _____
 Comments/Resolution: _____