

April 8, 2024

Maureen Doherty NB-Orange-Ulster BOCES 53 Gibson Road Goshen, NY 10924

Project Location: Balmville Project Number: Newburgh ECSD

Laboratory Work Order Number: 24C3075

Enclosed are results of analyses for samples received by the laboratory on March 27, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Project Manager



NB-Orange-Ulster BOCES 53 Gibson Road Goshen, NY 10924

ATTN: Maureen Doherty

REPORT DATE: 4/8/2024

PURCHASE ORDER NUMBER: A24-00300

PROJECT NUMBER: Newburgh ECSD

#### ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24C3075

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: Balmville

RM 21 BF         24C3075-01         Drinking Water         EPA 200.8 Rev 5.4           RM 21 DF         24C3075-20         Drinking Water         EPA 200.8 Rev 5.4           Faculty Lounge RS by Elevator         24C3075-04         Drinking Water         EPA 200.8 Rev 5.4           DF by Elevator         24C3075-05         Drinking Water         EPA 200.8 Rev 5.4           Cafe BF         24C3075-05         Drinking Water         EPA 200.8 Rev 5.4           Cafe DF         24C3075-07         Drinking Water         EPA 200.8 Rev 5.4           Faucet #1 on 3 bay sink         24C3075-08         Drinking Water         EPA 200.8 Rev 5.4           Faucet #2 on 3 bay sink         24C3075-09         Drinking Water         EPA 200.8 Rev 5.4           Faucet #2 on 3 bay sink         24C3075-10         Drinking Water         EPA 200.8 Rev 5.4           Faucet #3 on 3 bay sink         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #1         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #2         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           BF by Gym         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           BF #2 downstairs now bldg         24C3075-12         Drinking Water	FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
Faculty Lounge KS by Elevator   24C3075-03   Drinking Water   EPA 200.8 Rev 5.4	RM 21 BF	24C3075-01	Drinking Water		EPA 200.8 Rev 5	4
BF by Elevator   24C3075-04   Drinking Water   EPA 200.8 Rev 5.4	RM 21 DF	24C3075-02	Drinking Water		EPA 200.8 Rev 5	4
DF by Elevator 24C3075-05 Drinking Water EPA 200.8 Rev 5.4  Cafe DF 24C3075-06 Drinking Water EPA 200.8 Rev 5.4  Faucet #1 on 3 bay sink 24C3075-09 Drinking Water EPA 200.8 Rev 5.4  Faucet #2 on 3 bay sink 24C3075-09 Drinking Water EPA 200.8 Rev 5.4  Faucet #3 on 3 bay sink 24C3075-10 Drinking Water EPA 200.8 Rev 5.4  Faucet #3 on 3 bay sink 24C3075-10 Drinking Water EPA 200.8 Rev 5.4  Faucet #3 on 3 bay sink 24C3075-11 Drinking Water EPA 200.8 Rev 5.4  Health Office NS #1 24C3075-12 Drinking Water EPA 200.8 Rev 5.4  Health Office NS #2 24C3075-13 Drinking Water EPA 200.8 Rev 5.4  BF by Gym 24C3075-14 Drinking Water EPA 200.8 Rev 5.4  BF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4  BR 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4  Rm 34 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4  Rm 38 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4  BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4  BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4  BF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4  BF #2 downstairs now bldg 24C3075-23 Drinking Water EPA 200.8 Rev 5.4  Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4  Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4  Rm 33 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4  Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4  Rm 33 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 35 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 36 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 36 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 36 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 38 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 36 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	Faculty Lounge KS by Elevator	24C3075-03	Drinking Water		EPA 200.8 Rev 5	4
Cafe BF         24C3075-06         Drinking Water         EPA 200.8 Rev 5.4           Cafe DF         24C3075-07         Drinking Water         EPA 200.8 Rev 5.4           Faucet #1 on 3 bay sink         24C3075-08         Drinking Water         EPA 200.8 Rev 5.4           Faucet #2 on 3 bay sink         24C3075-10         Drinking Water         EPA 200.8 Rev 5.4           Faucet #3 on 3 bay sink         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           Rm 6 CS         24C3075-12         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #1         24C3075-12         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #2         24C3075-13         Drinking Water         EPA 200.8 Rev 5.4           Br by Gym         24C3075-14         Drinking Water         EPA 200.8 Rev 5.4           DF by Gym         24C3075-15         Drinking Water         EPA 200.8 Rev 5.4           Rm 41 CS         24C3075-16         Drinking Water         EPA 200.8 Rev 5.4           Rm 32 CS         24C3075-17         Drinking Water         EPA 200.8 Rev 5.4           Rm 37 CS         24C3075-19         Drinking Water         EPA 200.8 Rev 5.4           DF #1 downstairs now bldg         24C3075-20         Drinking Water         EPA 200.8 Rev 5.4	BF by Elevator	24C3075-04	Drinking Water		EPA 200.8 Rev 5	4
Cafe DF 24C3075-07 Drinking Water EPA 200.8 Rev 5.4 Faucet #1 on 3 bay sink 24C3075-08 Drinking Water EPA 200.8 Rev 5.4 Faucet #2 on 3 bay sink 24C3075-09 Drinking Water EPA 200.8 Rev 5.4 Faucet #3 on 3 bay sink 24C3075-10 Drinking Water EPA 200.8 Rev 5.4 Faucet #3 on 3 bay sink 24C3075-11 Drinking Water EPA 200.8 Rev 5.4 Health Office NS #1 24C3075-12 Drinking Water EPA 200.8 Rev 5.4 Health Office NS #1 24C3075-13 Drinking Water EPA 200.8 Rev 5.4 Health Office NS #2 24C3075-14 Drinking Water EPA 200.8 Rev 5.4 BF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4 DF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4 Rm 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4 Rm 41 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4 Rm 38 CS 24C3075-18 Drinking Water EPA 200.8 Rev 5.4 Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4 DF #1 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CF 24C3075-26 Drinking Water EPA 200.8 Rev 5.4	DF by Elevator	24C3075-05	Drinking Water		EPA 200.8 Rev 5	4
Faucet #1 on 3 bay sink         24C3075-08         Drinking Water         EPA 200.8 Rev 5.4           Faucet #2 on 3 bay sink         24C3075-10         Drinking Water         EPA 200.8 Rev 5.4           Faucet #3 on 3 bay sink         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           Rm 6 CS         24C3075-12         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #1         24C3075-12         Drinking Water         EPA 200.8 Rev 5.4           Ber by Gym         24C3075-13         Drinking Water         EPA 200.8 Rev 5.4           BF by Gym         24C3075-15         Drinking Water         EPA 200.8 Rev 5.4           DF by Gym         24C3075-15         Drinking Water         EPA 200.8 Rev 5.4           Rm 42 CS         24C3075-16         Drinking Water         EPA 200.8 Rev 5.4           Rm 31 CS         24C3075-17         Drinking Water         EPA 200.8 Rev 5.4           Rm 37 CS         24C3075-19         Drinking Water         EPA 200.8 Rev 5.4           DF #1 downstairs now bldg         24C3075-20         Drinking Water         EPA 200.8 Rev 5.4           DF #2 downstairs now bldg         24C3075-21         Drinking Water         EPA 200.8 Rev 5.4           DF #2 downstairs now bldg         24C3075-22         Drinking Water         EPA 200	Cafe BF	24C3075-06	Drinking Water		EPA 200.8 Rev 5	4
Faucet #2 on 3 bay sink         24C3075-09         Drinking Water         EPA 200.8 Rev 5.4           Faucet #3 on 3 bay sink         24C3075-10         Drinking Water         EPA 200.8 Rev 5.4           Rm 6 CS         24C3075-11         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #1         24C3075-12         Drinking Water         EPA 200.8 Rev 5.4           Health Office NS #2         24C3075-13         Drinking Water         EPA 200.8 Rev 5.4           BF by Gym         24C3075-15         Drinking Water         EPA 200.8 Rev 5.4           DF by Gym         24C3075-15         Drinking Water         EPA 200.8 Rev 5.4           Rm 42 CS         24C3075-16         Drinking Water         EPA 200.8 Rev 5.4           Rm 41 CS         24C3075-16         Drinking Water         EPA 200.8 Rev 5.4           Rm 37 CS         24C3075-17         Drinking Water         EPA 200.8 Rev 5.4           Rm 37 CS         24C3075-19         Drinking Water         EPA 200.8 Rev 5.4           DF #1 downstairs now bldg         24C3075-20         Drinking Water         EPA 200.8 Rev 5.4           BF #2 downstairs now bldg         24C3075-21         Drinking Water         EPA 200.8 Rev 5.4           Rm 30 CS         24C3075-22         Drinking Water         EPA 200.8 Rev 5.4 <td>Cafe DF</td> <td>24C3075-07</td> <td>Drinking Water</td> <td></td> <td>EPA 200.8 Rev 5</td> <td>4</td>	Cafe DF	24C3075-07	Drinking Water		EPA 200.8 Rev 5	4
Faucet #3 on 3 bay sink	Faucet #1 on 3 bay sink	24C3075-08	Drinking Water		EPA 200.8 Rev 5	4
Rm 6 CS       24C3075-11       Drinking Water       EPA 200.8 Rev 5.4         Health Office NS #1       24C3075-12       Drinking Water       EPA 200.8 Rev 5.4         Health Office NS #2       24C3075-13       Drinking Water       EPA 200.8 Rev 5.4         BF by Gym       24C3075-14       Drinking Water       EPA 200.8 Rev 5.4         DF by Gym       24C3075-15       Drinking Water       EPA 200.8 Rev 5.4         Rm 42 CS       24C3075-16       Drinking Water       EPA 200.8 Rev 5.4         Rm 41 CS       24C3075-17       Drinking Water       EPA 200.8 Rev 5.4         Rm 38 CS       24C3075-18       Drinking Water       EPA 200.8 Rev 5.4         Rm 37 CS       24C3075-19       Drinking Water       EPA 200.8 Rev 5.4         DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev	Faucet #2 on 3 bay sink	24C3075-09	Drinking Water		EPA 200.8 Rev 5.	4
Health Office NS #1 24C3075-12 Drinking Water EPA 200.8 Rev 5.4 Health Office NS #2 24C3075-13 Drinking Water EPA 200.8 Rev 5.4 BF by Gym 24C3075-14 Drinking Water EPA 200.8 Rev 5.4 DF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4 Rm 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4 Rm 41 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4 Rm 38 CS 24C3075-18 Drinking Water EPA 200.8 Rev 5.4 Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4 DF #1 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-23 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 32 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	Faucet #3 on 3 bay sink	24C3075-10	Drinking Water		EPA 200.8 Rev 5	4
Health Office NS #2 24C3075-13 Drinking Water EPA 200.8 Rev 5.4  BF by Gym 24C3075-14 Drinking Water EPA 200.8 Rev 5.4  DF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4  Rm 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4  Rm 41 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4  Rm 38 CS 24C3075-18 Drinking Water EPA 200.8 Rev 5.4  Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4  DF #1 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4  BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4  DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4  Rm 30 CS 24C3075-23 Drinking Water EPA 200.8 Rev 5.4  Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4  Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4  Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4  Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4  Rm 31 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 35 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4  Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4  Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	Rm 6 CS	24C3075-11	Drinking Water		EPA 200.8 Rev 5	4
BF by Gym 24C3075-14 Drinking Water EPA 200.8 Rev 5.4 DF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4 Rm 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4 Rm 41 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4 Rm 38 CS 24C3075-18 Drinking Water EPA 200.8 Rev 5.4 Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4 DF #1 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF EPA 200.8 Rev 5.4 Rm 31 DF EPA 200.8 Rev 5.4	Health Office NS #1	24C3075-12	Drinking Water		EPA 200.8 Rev 5	4
DF by Gym 24C3075-15 Drinking Water EPA 200.8 Rev 5.4 Rm 42 CS 24C3075-16 Drinking Water EPA 200.8 Rev 5.4 Rm 41 CS 24C3075-17 Drinking Water EPA 200.8 Rev 5.4 Rm 38 CS 24C3075-18 Drinking Water EPA 200.8 Rev 5.4 Rm 37 CS 24C3075-19 Drinking Water EPA 200.8 Rev 5.4 DF #1 downstairs now bldg 24C3075-20 Drinking Water EPA 200.8 Rev 5.4 BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-23 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF EPA 200.8 Rev 5.4	Health Office NS #2	24C3075-13	Drinking Water		EPA 200.8 Rev 5.	4
Rm 42 CS       24C3075-16       Drinking Water       EPA 200.8 Rev 5.4         Rm 41 CS       24C3075-17       Drinking Water       EPA 200.8 Rev 5.4         Rm 38 CS       24C3075-18       Drinking Water       EPA 200.8 Rev 5.4         Rm 37 CS       24C3075-19       Drinking Water       EPA 200.8 Rev 5.4         DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	BF by Gym	24C3075-14	Drinking Water		EPA 200.8 Rev 5	4
Rm 41 CS       24C3075-17       Drinking Water       EPA 200.8 Rev 5.4         Rm 38 CS       24C3075-18       Drinking Water       EPA 200.8 Rev 5.4         Rm 37 CS       24C3075-19       Drinking Water       EPA 200.8 Rev 5.4         DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	DF by Gym	24C3075-15	Drinking Water		EPA 200.8 Rev 5.	4
Rm 38 CS       24C3075-18       Drinking Water       EPA 200.8 Rev 5.4         Rm 37 CS       24C3075-19       Drinking Water       EPA 200.8 Rev 5.4         DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 42 CS	24C3075-16	Drinking Water		EPA 200.8 Rev 5	4
Rm 37 CS       24C3075-19       Drinking Water       EPA 200.8 Rev 5.4         DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 41 CS	24C3075-17	Drinking Water		EPA 200.8 Rev 5.	4
DF #1 downstairs now bldg       24C3075-20       Drinking Water       EPA 200.8 Rev 5.4         BF #2 downstairs now bldg       24C3075-21       Drinking Water       EPA 200.8 Rev 5.4         DF #2 downstairs now bldg       24C3075-22       Drinking Water       EPA 200.8 Rev 5.4         Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 38 CS	24C3075-18	Drinking Water		EPA 200.8 Rev 5.	4
BF #2 downstairs now bldg 24C3075-21 Drinking Water EPA 200.8 Rev 5.4 DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-23 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	Rm 37 CS	24C3075-19	Drinking Water		EPA 200.8 Rev 5.	4
DF #2 downstairs now bldg 24C3075-22 Drinking Water EPA 200.8 Rev 5.4 Rm 30 CS 24C3075-23 Drinking Water EPA 200.8 Rev 5.4 Rm 31 CS 24C3075-24 Drinking Water EPA 200.8 Rev 5.4 Rm 32 CS 24C3075-25 Drinking Water EPA 200.8 Rev 5.4 Rm 33 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 35 CS 24C3075-26 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF 24C3075-27 Drinking Water EPA 200.8 Rev 5.4 Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	DF #1 downstairs now bldg	24C3075-20	Drinking Water		EPA 200.8 Rev 5.	4
Rm 30 CS       24C3075-23       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	BF #2 downstairs now bldg	24C3075-21	Drinking Water		EPA 200.8 Rev 5.	4
Rm 31 CS       24C3075-24       Drinking Water       EPA 200.8 Rev 5.4         Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	DF #2 downstairs now bldg	24C3075-22	Drinking Water		EPA 200.8 Rev 5.	4
Rm 32 CS       24C3075-25       Drinking Water       EPA 200.8 Rev 5.4         Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 30 CS	24C3075-23	Drinking Water		EPA 200.8 Rev 5.	4
Rm 33 CS       24C3075-26       Drinking Water       EPA 200.8 Rev 5.4         Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 31 CS	24C3075-24	Drinking Water		EPA 200.8 Rev 5.	4
Rm 35 CS       24C3075-27       Drinking Water       EPA 200.8 Rev 5.4         Rm 31 DF       24C3075-28       Drinking Water       EPA 200.8 Rev 5.4	Rm 32 CS	24C3075-25	Drinking Water		EPA 200.8 Rev 5.	4
Rm 31 DF 24C3075-28 Drinking Water EPA 200.8 Rev 5.4	Rm 33 CS	24C3075-26	Drinking Water		EPA 200.8 Rev 5	4
	Rm 35 CS	24C3075-27	Drinking Water		EPA 200.8 Rev 5.	4
Rm 30 DF 24C3075-29 Drinking Water EPA 200.8 Rev 5.4	Rm 31 DF	24C3075-28	Drinking Water		EPA 200.8 Rev 5	4
	Rm 30 DF	24C3075-29	Drinking Water		EPA 200.8 Rev 5	4





#### CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.

Felicia Morgan-Nichols Project Manager



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: RM 21 BF

Sampled: 3/27/2024 06:14

Sample ID: 24C3075-01
Sample Matrix: Drinking Water

Metals Analys	es (Total)
---------------	------------

	MCL/SMCL									Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:45	IC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

**Field Sample #: RM 21 DF** Sampled: 3/27/2024 06:14

Sample ID: 24C3075-02
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:51	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Faculty Lounge KS by Elevator Sampled: 3/27/2024 06:11

Sample ID: 24C3075-03
Sample Matrix: Drinking Water

Metals Analyses (Total)													
MCL/SMCL								Date	Date/Time				
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst		
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:53	JC		



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: BF by Elevator

Sampled: 3/27/2024 06:11

Sample ID: 24C3075-04
Sample Matrix: Drinking Water

Metals Analyses (Total)													
				MCL/SMCL					Date	Date/Time			
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst		
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:55	JC		



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: DF by Elevator Sampled: 3/27/2024 06:12

Sample ID: 24C3075-05
Sample Matrix: Drinking Water

						, ,					
				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:57	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Cafe BF Sampled: 3/27/2024 06:08

Sample ID: 24C3075-06
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time		
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst	
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 15:59	JC	



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Cafe DF Sampled: 3/27/2024 06:08

Sample ID: 24C3075-07
Sample Matrix: Drinking Water

•

Metals A	Analyses	(Total)
----------	----------	---------

MCL/SMCL								Date	Date/Time	
Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead	ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:01	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Faucet #1 on 3 bay sink Sampled: 3/27/2024 06:05

Sample ID: 24C3075-08
Sample Matrix: Drinking Water

Metals Analyses (Total)													
				MCL/SMCL				Date	Date/Time				
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst		
Lead		2.7	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:03	JC		



Project Location: Balmville Sample Description: Work Order: 24C3075

 $\mu g/L$ 

Date Received: 3/27/2024

Lead

Sampled: 3/27/2024 06:06 Field Sample #: Faucet #2 on 3 bay sink

RL

1.0

15

Results

ND

Sample ID: 24C3075-09 Sample Matrix: Drinking Water

Analyte

I	Metals Anal	lyses (Total)					
MCL/SMCL					Date	Date/Time	
	Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst

EPA 200.8 Rev 5.4

4/3/24

4/5/24 16:05

JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Faucet #3 on 3 bay sink Sampled: 3/27/2024 06:06

Sample ID: 24C3075-10
Sample Matrix: Drinking Water

Metals Analyses (	(Total)

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:08	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 6 CS

Sampled: 3/27/2024 06:03

Sample ID: 24C3075-11

Sample Matrix: Drinking Water

		I	MCL/SMCL					Date	Date/Time	
Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead	ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:14	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Health Office NS #1 Sampled: 3/27/2024 06:01

Sample ID: 24C3075-12
Sample Matrix: Drinking Water

					Metals Ana	lyses (Total)					
		Date	Date/Time								
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		4.5	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:16	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Health Office NS #2 Sampled: 3/27/2024 06:01

Sample ID: 24C3075-13
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:18	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024 Field Sample #: BF by Gym

Sampled: 3/27/2024 06:32

Sample ID: 24C3075-14
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:20	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024 Field Sample #: DF by Gym

Sampled: 3/27/2024 06:32

Sample ID: 24C3075-15
Sample Matrix: Drinking Water

			1	MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	пе/Г.	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:22	IC.



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 42 CS

Sampled: 3/27/2024 06:29

Sample ID: 24C3075-16
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:24	IC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 41 CS

Sampled: 3/27/2024 06:30

Sample ID: 24C3075-17
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 16:26	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 38 CS

Sampled: 3/27/2024 06:30

Sample ID: 24C3075-18
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:30	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 37 CS

Sampled: 3/27/2024 06:31

Sample ID: 24C3075-19
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:32	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: DF #1 downstairs now bldg Sampled: 3/27/2024 06:22

Sample ID: 24C3075-20
Sample Matrix: Drinking Water

					Metals Ana	lyses (Total)					
				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:41	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: BF #2 downstairs now bldg Sampled: 3/27/2024 06:22

Sample ID: 24C3075-21
Sample Matrix: Drinking Water

					Metals Ana	lyses (Total)						
			:	MCL/SMCL					Date	Date/Time		
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst	
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:43	JC	



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: DF #2 downstairs now bldg Sampled: 3/27/2024 06:22

Sample ID: 24C3075-22
Sample Matrix: Drinking Water

					Metals Ana	lyses (Total)					
				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:45	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 30 CS

Sampled: 3/27/2024 06:18

Sample ID: 24C3075-23
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:47	IC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 31 CS

Sampled: 3/27/2024 06:20

Sample ID: 24C3075-24
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:53	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 32 CS

Sampled: 3/27/2024 06:24

Sample ID: 24C3075-25
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:55	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 33 CS

Sampled: 3/27/2024 06:25

Sample ID: 24C3075-26
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		4.6	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:57	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 35 CS

Sampled: 3/27/2024 06:26

Sample ID: 24C3075-27
Sample Matrix: Drinking Water

Metals Anal	yses (	(Total)
-------------	--------	---------

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	μg/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 17:59	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 31 DF

Sampled: 3/27/2024 06:21

Sample ID: 24C3075-28
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 18:01	JC



Project Location: Balmville Sample Description: Work Order: 24C3075

Date Received: 3/27/2024

Field Sample #: Rm 30 DF

Sampled: 3/27/2024 06:19

Sample ID: 24C3075-29
Sample Matrix: Drinking Water

				MCL/SMCL					Date	Date/Time	
	Analyte	Results	RL		Units	Dilution	Flag/Qual	Method	Prepared	Analyzed	Analyst
Lead		ND	1.0	15	ug/L	1		EPA 200.8 Rev 5.4	4/3/24	4/5/24 18:03	JC



#### FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.



## CERTIFICATIONS

## Certified Analyses included in this Report

**Analyte** Certifications

## EPA 200.8 Rev 5.4 in Drinking Water

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical	Services, LCC operates under the following certifications and ac		
Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024

Pace® Location Requested (City/State): Newburgh, NY	(City/State		CHAIN-OF-CUSTODY Analytical Request Document Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields		
Company Name: Orange-Ulster BOCES		Contact/Report To: Maureen Doherty			
Street Address:		Phone#: 845-781-4887			
53 Gibson Road		E-Mail: Maureen.Doherty@ouboces.org	9	1000	ス O フ C
Goshen, NY 10924		Cc E-Mail: Halina.redner@ouboces.org		L - C	00-0
Customer Project #:		Invoice to: Halina Redner			
Project Name:		halina redner@ouboces org		Specify Container Size **	(4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore,
Site Collection Info/Facility ID (as applicable):		Purchase Order # (if		Identify Container Preservative Type***	*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4
Balmville		applicable): AZ4-UU3UU		Analysis Requested	(4) HCJ, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Add, (10) MeOH, (11) Other
Time Zone Collected: [ ] AK	Xer	County / State origin of sample(s): Orange County / New York	county / New York		Proj. Mgr:
	Regulatory Program (DW, RCRA, etc.) as applicable: DOH	.) as applicable:	Reportable X Yes [] No		AcctNum / Client ID:
[ ] Level II [ ] Level IV Rush (Pre-approval required):	oval required):		DW PWSID # or WW Permit # as applicable:	ng	on Table #:
	Date Results		Field Filtered (if applicable): [ ] Yes XNo	est	Profile / Template:
* Natrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Solf/Solid (SS), Oil (O1), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Children (ST), Chil	W), Wastewater (WW	, Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS)		d T	Prelog / Bottle Ord. ID:
Customer Sample ID	Matrix * Comp /	Composite Start  Date   Time	Collected or Composite End # Cont. Residual Chlorine  Date Time # Cont. Result Units	Lea	Sample Comment
Rm 21 BF	DW G		7 614	X	
Rm 21 DF	DW G		5/127 614	×	
Faculty Lounge KS by Elevator	DW G	3	127 611	X	
BF by Elevator	DW G		113 7611	×	
DF by Elevator	DW G		3/27 6/2	X	
Cafe BF	DW G	(.)	3/27 608	×	
Cafe DF	DW G		3/27 606	×	
Raucet #1 on 3 bay sink	DW G		3/27 605	×	
Faucet #2 on 3 bay sink	DW G		3/27 606	X	
Faucet #3 on 3 bay sink	DW G		3/27 606	×	
Additional Instructions from Pace®:		Collected By: Printed Name	25/2	Customer Remarks / Special Conditions / Possible Hazards:	
		Signature	an (	# Coolers: Thermometer ID: Correction Factor (°C): Obs. Te	Obs. Temp. (*C): Corrected Jemp. (*C): [ ] On Ice
Relinquished by/Company: (Signature)		Date/Time: Received	Received by/Company: (SIR) Bure)	Ce 13/27/24 11:00	Tracking Number:
Relinquished by/Compthy (Signature)	do	Date/Time 27/24 15/5 Recon	The Royal Signature Property	143/ 143/2°	Delivered by: [ ] In- Person [ ] Courier
Relinquished by/Company: Asig fature)	2	Date/Time: Receiv	(Signature)	15/5	[ ] FedEX [ ] UPS [ ] Other
Pate / Imms:   Pate	gment and accept	Date/Time: Receive and Conditions found a	ved************************************	ace-terms-and-conditions/	Page: of 3 ENV-FRM-CORQ-0019_v02_110123 ©
Tabilitating a satisfies sia and character for the satisfies a section of the	Pilicia alla acceba	the of the land land and delined the land of the land	the state of the s		

= 5 Z 1 2 2 Rm 38 CS Rm 41 CS DF by Gym BF by Gym Health office NS #2 BF # 1 downstairs now bldg Rm 37 CS Rm 42 CS Health office NS #1 Rm 6 CS 53 Gibson Road Goshen, NY 10924 Balmville site Collection Info/Facility ID (as applicable): ubmitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions, Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT) [ ] Level II ime Zone Collected: [ ] AK Newburgh ECSD ustomer Project #: Matrix Codes (Insert in Matrix box below): Prinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bloassay (B), Vapor (V), Surface Water (SW), Sediment (SED) [ ] EQUIS oject Name: mpany Name: Orange-Ulster BOCES Pace Newburgh, NY Pace® Location Requested (City/State): [ ]PT [ ] Level IV IM[ ] Rush (Pre-approval required): Date Results DOH Regulatory Program (DW, RCRA, etc.) as applicable: ]Same Day [ ]1 Day [ ]2 Day [ ]3 Day Other [ ]CT X DW G DW G DW DW DW DW DW DW DW DW G G G 9 Grab / 0 G G G County / State origin of sample(s): Orange County / New York Cc E-Mail: Halina.redner@ouboces.org halina.redner@ouboces.org Phone #: 845-781-4887 Contact/Report To: Maureen Doherty **CHAIN-OF-CUSTODY Analytical Request Document** applicable): A24-00300 nvoice to: Halina Redner -Mail: Maureen.Doherty@ouboces.org Composite Start Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields Ŝ Collected By: Printed Name Ct/2 DW PWSID # or WW Permit # as applicable: Collected or Composite End Field Filtered (if applicable): [ ] Yes No 630 632 632 60 603 629 60 Reportable Yes [] No # Cont 2015 Residual Chlorine Customer Remarks / Special Conditions / Possible Hazards: Lead Testing Correction Factor (°C): LAB USE ONLY- Affix Workorder/Login Label Here Scan QR Code for instructions 7.0 Obs. Temp. (°C): Delivered by: [ ] In- Person [ ] Courier ENV-FRM-CORQ-0019\_v02\_110123 © Lab Use Only \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCJ, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Add, (10) MeOH, (11) Other \*\*Container Size: (1) 11, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 90mL, (10) Other [ ] FedEX [ ] UPS [ ] Other Profile / Template AcctNum / Client ID: Proj. Mgr: relog / Bottle Ord. ID: Sample Comment X Jon Ice Preservation non-conformance identified for sample.

Rm 32 CS 25 Rm 31 CS 14 Rm 30 CS 3 DF # 2 downstairs now bldg BF # 2 downstairs now bldg 26 Rm 35 CS 77 Rm 33 CS DF # 1 downstairs now bldg 53 Gibson Road Goshen, NY 10924 Additional Instructions from Pace® Balmville Data Deliverables: Site Collection Info/Facility ID (as applicable) Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Soild (S), Oil (OL), Wipe (WP), Tissue (TS), Bloassay (B), Vapor (V), Surface Water (SW), Sediment (SED), [ ] Level II îme Zone Collected: [ ] AK lewburgh ECSD Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT) [ ] EQUIS roject Name: ustomer Project #: 3 mpany Name: Orange-Ulster BOCES 3 Pace Newburgh, NY nitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace\* Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions. shed by/Company: (Signature) 30 Pace® Location Requested (City/State): [ ]PT [ ] Level IV IM[] Rush (Pre-approval required): [ ]Same Day [ ]1 Day [ ]2 Day [ ]3 Day Other Regulatory Program (DW, RCRA, etc.) as applicable: [ ] CT X DW Matrix \* G G G Comp / G 0 G G **CHAIN-OF-CUSTODY Analytical Request Document** Cc E-Mail: Halina.redner@ouboces.org County / State origin of sample(s): applicable): A24-00300 nalina.redner@ouboces.org nvoice to: Halina Redner -Mail: Maureen.Doherty@ouboces.org hone #: 845-781-4887 Contact/Report To: Maureen Doherty Composite Start **Printed Name** 60: Orange County / New York 3/27 727 DW PWSID # or WW Permit # as applicable: Collected or Composite End Field Filtered (if applicable): [ ] Yes 622 622 43 622 620 618 Time Reportable Yes [] No wish # Cont Lead Testing Specify Container Size \*\* 24L3075
Scan QR Code for instructions Correction Factor (°C): Hazards 11:00 Obs. Temp. (°C): Delivered by: [ ] In- Person [ ] Courier Page: ENV-FRM-CORQ-0019\_v02\_110123 @ Lab Use Only \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other \*\*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, 8) TerraCore, (9) 90mL, (10) Other [ ] FedEX [ ] UPS [ ] Other Proj. Mgr: AcctNum / Client ID: elog / Bottle Ord. ID: ofile / Template: Sample Comment Preservation non-conformance identified

DC#\_Title: ENV-FRM-NEWB-0002 Sample Condition Upon Receipt Form

Effective Date: 7/21/2022

# Sample Condition Upon Receipt Form (SCUR)

Project # 2403 Client: Ou B	307 <u>5</u>	Date and Initials of person:  Examining contents:  Label:  Deliver to location:
Thermometer Used:	Date: 3 27 0	24 Time: 130 Initials: 5E
State of Origin:		(Actual) Samples on ice, cooling process has begun
Cooler #1 Temp.°C(Visual)(C		Other
Courier: Fed Ex UPS USPS Shipping Method: First Overnight Priority O  Other  Tracking #	evernight   Standard	mmercial □Pace Overnight □ Ground
Custody Seal on Cooler/Box Present: Yes	No Seals in	tact: Yes No Ice: Wet Blue Melted None
Packing Material: Bubble Wrap Bubble Bag	s None	Other
Samples were collected by Pace employee	☐ Yes ☐	No N/A
Samples were collected by Face employee		Comments:
Chain of Custody Present	PYes □ No □ N/A	
Chain of Custody Filled Out	ØYes □ No □ N/A	
	EYes □ No □ N/A	
Sampler Name and Signature on COC	EYes □ No □ N/A	
Samples Arrived within Hold Time	Yes No NA	
Rush TAT requested on COC	□Yes □No □ N/A	
Sufficient Volume	ØYes □ No □ N/A	
Correct Containers Used	DY'es   No   N/A	
Containers Intact	Pres   No   N/A	CAN THE RESIDENCE OF THE PROPERTY OF THE PROPE
Sample Labels match COC (sample IDs & date/time of	f □Yes □ No □ N/A	
collection) All containers needing acid/base preservation have been checked. All Containers needing preservation are found to be in compliance with EPA recommendation:  Exceptions: Vials, Microbiology, O&G, 1	□Yes □ No □ N/A	Preservation Information: Preservative: Lot #/Trace #: Date:Time: Initials:
Headspace in VOA Vials? ( >6mm):	□Yes □ No □NA	
Trip Blank Present:	□Yes □ No ☑N/A	
Additional Login Comments:		
Client notification/ Resolution		
Person Contacted:		Date/Time:
Comments/Resolution:		